

## 99th RSC Region 5, Zone 3 Inventory

Key: Black - Current, Blue - Due, Red - Failed, Yellow - Added to Contract, Grey - Removed from Contract

VA006 USARC Charlottesville 3502 Bennetts Creek Park Rd. Suffolk, VA 23435									Column1
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	Column1
B-1	Boiler	Weil-McLain	NB	CA-1VA006	10/23/2019	No		Repair/replace return temp sensor, can't light. Install E-Stop.	NEEDS REPAIRS & RE-CERTIFICATION
B-2	Boiler	Weil-McLain	NB	CA-2VA006	10/23/2019	No		Repair/replace circulating pump, can't light. Install E-Stop.	NEEDS REPAIRS & RE-CERTIFICATION
VA009 USARC Suffolk 3502 Bennetts Creek Park Rd. Suffolk, VA 23435 Removed from contract									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	Column1
2259	Boiler	Munchkin	SN	E17Q21809				Model 1133500	
2260	Boiler	Munchkin	SN	F01Q24274				Model 199M R2	
VA011 USARC Culpeper 3502 Bennetts Creek Park Rd. Suffolk, VA 23435									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	Column1
	Boiler	Aerco	SN	454-08-0222	10/24/2019	No		Install E-Stop, rerun safety valve discharge piping.	BOILER WILL PASS WHEN REPAIRS AND RECERTIFICATION HAPPEN
VA049 USARC North Chesterfield 3502 Bennetts Creek Park Rd. Suffolk, VA 23435									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	Column1
	Boiler				12/9/2019				
	Boiler				12/9/2019				
	Boiler				12/9/2019				
	Boiler				12/9/2019				
	Air Receiver	Stoystown	NB	78033	10/24/2019	Yes	10/24/2022		
VA050 USARC Richmond 6002 Strathmore Rd. Richmond, VA 23234									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	Column1
2343 (HB-1)	Boiler	Munchkin	SN	G01P17267	10/24/2019	No		Would not light for operational.	NEEDS REPAIRS & RE-CERTIFIED
(HB-2)	Boiler	Munchkin	SN	G01P17238	10/24/2019	Yes	10/24/2020		PASSED CERTIFICATION
VA099 USARC Bedford 1117 Harmony Ln. Bedford, VA 24523									
Property Number	Equipment Type	Manufacturer	NB or SN	Identifying Number	Inspection Date	Certified	Expiration Date	Notes	Column1
2357 (WH-2)	Condensing Boiler	Lochinvar	SN	A13H20046146	10/23/2019	Yes	10/23/2020		PASSED CERTIFICATION
2358 (WH-1)	Condensing Boiler	Lochinvar	SN	J12H20236336	10/23/2019	Yes	10/23/2020		PASSED CERTIFICATION
2359 (HWB-1)	Condensing Boiler	Lochinvar	SN	K12H10234406	10/23/2019	Yes	10/23/2020		PASSED CERTIFICATION
2360 (HWB-2)	Condensing Boiler	Lochinvar	SN	K12H10234409	10/23/2019	Yes	10/23/2020		PASSED CERTIFICATION
	Air Receiver	Manchester	NB	1377185	10/23/2019	Yes	10/23/2022		PASSED CERTIFICATION