

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

SITE AND BLDG #: PA027

MECHANIC
SIGNATURE:*Pat Bernhard*

DATE: 11/3/2025

LOCATION/RM #:	WO# 20437	ASSET #	See notes	START TIME: 12:00PM	FINISH TIME: 1:30PM
----------------	-----------	---------	-----------	---------------------	---------------------

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
		YES	NO	SPECIAL INSTRUCTIONS	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Remove debris from air screen and clean underneath unit.	●			
2	Wash coil with coil cleaning solution - Rinse Thoroughly	●			
3	Straighten fin tubes with fin comb, as needed.	●			
4	Check electrical connections for tightness.	●			
5	Check mounting base for tightness.	●			
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	●			
7	Inspect all piping for leaks and tighten loose connections.	●			
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	●			
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature and Humidity	●		Room temp <u>70</u>	Room Humidity _____ %
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	●			
11	Clean up work area.	●			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes: Asset3249,3257,3258 changed filte