

Date: 1-26-24

Region: 4A
FAC ID: PA027

CSS No.: 96422
Maximo WO No.: 14972

Asset #:

Priority: 2



Original Work Request:

Repair emergency battery back light fixtures. Emergency ceiling lights need to have the back up batteries replaced as they were not working during a recent power outage. Diagrams are attached as to where the lights are located.

Description of Repairs Needed:

Replace drivers on 16 existing light fixtures. Replacements include 14 - 14 watt drivers and 2 - 7 watt drivers on the existing fixtures

Labor:

	Labor Hrs	Labor Rate	Total
Tech (1)	12	\$ 100.00	\$ 1,200.00
			\$ -

Material List:

	Quantity	Cost	Total
14 Watt, LED Emrg Batt Pk (EBPLED14W)	14	\$ 305.99	\$ 4,283.86
7 Watt, LED Emrg Batt Pk (EBPLED7W)	2	\$ 221.99	\$ 443.98
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$1,200.00	\$4,727.84	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$5,927.84	\$711.34	\$355.67	\$6,994.85