

Date: 2-5-26



Region: 4A

FEMS/CSS No.: 3496968

FAC ID: PA027

Maximo WO No.: 21212

Asset #:

Priority: 2

Original Work Request:

Numerous heating units (fin tubes) in the offices on the mai level and 2nd floor do not have any heat coming out of them

Description of Repairs Needed:

Proposal is based on the invoice to investigate/repair heaters that were not working. Contractor was able to manually open actuators to get heaters working for now.

Labor:

	Labor Hrs	Labor Rate	Total
Tech (1)	3	\$ 179.00	\$ 537.00
Trip Charge	1	\$ 64.00	\$ 64.00
Fuel Surcharge	1	\$ 12.00	\$ 12.00

Material List:

	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:

	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$613.00	\$0.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$613.00	\$73.56	\$36.78	\$723.34