

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

INSPECTION, TESTING, AND CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: PA027 Date of Visit: 03/05/2019

Contractor Personnel on Site:

1. <u>Joseph Benz</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Work Performed:

Inspection, Testing, and Certification

1. <u>Backflow Prevention Testing (Qty 2) (Annual) WO 7283 Asset 7255</u>
2. <u>WO 7283 Asset 7258</u>
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Joseph Benz Date: 03/05/2019

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Shadowens, Gary Date: 5 mar 19

Signed: 

E-Mail: Gary.l.shadowens.civ@mail.mil

ASSE International
Reduced Pressure Principle Backflow Preventer (RP)
ASSE Standard #1013 Field Test Report

Owner of Property PA027 ARMY RESERVE CENTER

Address 950 NEW CASTLE RD.

City FARRELL State PA Zip Code 16121

Occupant of Property (if different from owner) _____

Occupant Address _____

City _____ State _____ Zip Code _____

Manufacturer of Assembly: WILKINS Model #: 975XL

Size of Assembly: 3/4" Serial #: W050380

Location of Assembly and Equipment or System Application: MAINTENANCE ROOM
EQUIPMENT ISOLATION - BOILER

Test Equipment:

Manufacturer: WATTS Model #: TK9A Serial #: 0104817

Calibration Date: 04/25/2018

Date test was performed: 03/05/2019 Time test was performed: 10:00 AM Static Line Pressure: 50 PSI

	Check Valve #2	Shutoff valve #2	Check Valve #1	Pressure Differential Relief Valve
Initial Test	Leaking () Closed Tight (✓)	Leaking () Closed Tight (✓)	Leaking () Closed Tight (✓) Pressure Drop Across Check Valve #1 <u>8.0</u> psid	Opened at <u>2.4</u> psid
Describe parts and repairs when needed				
Final Test	Leaking () Closed Tight (✓)	Leaking () Closed Tight (✓)	Leaking () Closed Tight (✓) Pressure Drop Across Check Valve #1 <u>8.0</u> psid	Opened at <u>2.4</u> psid

Certified Tester (print) Joseph G. Benz

Address 5225 Library Rd., Ste 146

City Bethel Park State PA Zip 15102

Phone #: (412)852-4966


License #: H.P. 0683 Certification # ASSE5429

Assembly Final Test Performance

Pass

Fail

Signature _____



Date: 03/05/2019

Comments or Recommendations (continue to other side, if needed): _____

ASSE International

Double Check Backflow Prevention Assembly (DC)

ASSE Standard #1015 Field Test Report

Owner of Property PA027 ARMY RESERVE CENTER

Address 950 NEW CASTLE RD

City FARRELL State PA Zip Code 16121

Occupant of Property (if different from owner)

Occupant Address

City _____ State _____ Zip Code _____

Manufacturer of Assembly: WATTS Model #: 007M1QT

Size of Assembly: 2" Serial #: 189117

Location of Assembly and Equipment or System Application: MAINTENANCE ROOM
DOMESTIC WATER SERVICE CONTAINMENT

Test Equipment:

Manufacturer: WATTS Model #: TK9A Serial #: 0104817

Calibration Date: 04/25/2018

Date test was performed: 03/05/2019 Time test was performed: 9:50 AM Static Line Pressure: 45 PSI

	Check Valve #1	Check Valve #2	Shutoff valve #2
Initial Test	Leaking () psid <u>2.0</u> Closed Tight (✓)	Leaking () psid <u>2.0</u> Closed Tight (✓)	Leaking () Closed Tight (✓)
Describe parts and repairs when needed			
Final Test	Leaking () psid <u>2.0</u> Closed Tight (✓)	Leaking () psid <u>2.0</u> Closed Tight (✓)	Leaking () Closed Tight (✓)

Certified Tester (print) Joseph G Benz

Address 5225 Library Road, Suite 146

City Bethel Park State PA Zip 15102

Phone #: (412)852-4966

License #: H.P. 0683 Certification # ASSE5429


Assembly Final Performance

Pass



Fail



Signature  Date: 03/05/2019

Comments or Recommendations (continue to other side, if needed):

MANUF. WATTS MODEL 007M1
SERIAL # 189117 SIZE 2."
TEST DATE 3/5/19 TIME 9:50A
TESTER ASSESS429 LINE PSI 45
CK1 2.0 CK2 2.0 VALVE OPEN 1/4

MANUF. WILKINS MODEL 975XL

SERIAL # W050380 SIZE 3/4"

TEST DATE 3/5/19 TIME 10:00A

TESTER ASSESS427 LINE PSI 50

CK1 8.0 CK2 2.0 VALVE OPEN 2.4



WATTS

WATTS
WATER
TECHNOLOGY
(412) 852-4966

WATTS
WATER
TECHNOLOGY
1130