

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #: FL 042-028060LOCATION/RM #: CM 1WO# 1057ASSET # 2066MECHANIC
SIGNATURE: DATE: 8/15/15START TIME: 10:30FINISH TIME: 10:35

ITEM/ACT.	DESCRIPTION	STATUS (COMPLETED / IN PROGRESS / NOT YET PERFORMED)	SPECIAL INSTRUCTIONS		NOTES/ACTIONS (INCLUDES COMPLETED, OUTSTANDING, AND PROVIDED BY PARTNER)
			YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		<input checked="" type="checkbox"/>		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		<input checked="" type="checkbox"/>		
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Start and stop fan with local switch		<input checked="" type="checkbox"/>		
2	Check motor and fan shaft bearings for noise, vibration, overheating. Lubricate bearings.		<input checked="" type="checkbox"/>		
3	Inspect, adjust belts and pulleys. Replace belt as needed.		<input checked="" type="checkbox"/>		
4	Clean dampers, lubricate pivot points (annually) and inspect linkages for tightness.		<input checked="" type="checkbox"/>		
5	Inspect fan for bent blades, unbalance, excessive noise and vibration		<input checked="" type="checkbox"/>		
6	Clean fan as needed.		<input checked="" type="checkbox"/>		
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.		<input checked="" type="checkbox"/>		
8	Repair as needed		<input checked="" type="checkbox"/>		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

