

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #: P 051 -07

LOCATION/RM #: P-111 WO# 10211 ASSET # 2390

MECHANIC SIGNATURE: [Signature]

DATE: 9/12/11

START TIME: 0600

FINISH TIME: 600

ITEM	DESCRIPTION	YES	NO	REMARKS
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Schedule and coordinate work with operating personnel.			
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
4	Open and tag switch.			
5	Inspect visual condition of wiring. Look for evidence of overheating.			
6	Check for proper light operation.			
7	Test operation of automatic switches/ time clock/ photocells if applicable.			
8	Inspect light pole and mounting devices for deficiencies.			
9	For any noted deficiency, takes pictures and open corrective maintenance ticket.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

310