

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: P 058

Date of Visit: 9/12/19

Contractor Personnel on Site:

1. Tony Lazzarus
2. Jim Gerstner
3. Scott Warr

4. _____
5. _____
6. _____

Work Performed:

Other Recurring Services

1. 10729
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Tony Lazzarus

Date: 9/12/19

Signed: Tony

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: TIMOTHY S PETERS

Date: 12 SEP 19

Signed: [Signature]

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #:

PA 055-01

LOCATION/RM #:

MEL

WO#

10724

ASSET #

7421

MECHANIC
SIGNATURE:


DATE:

2/12/19

START TIME: 0630

FINISH TIME: 0830

GENERAL INSTRUCTIONS		WORK COMPLETION	
NO.	DESCRIPTION	YES	NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		
2	Schedule and coordinate work with operating personnel.		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		
TO BE PERFORMED AT EACH INSPECTION SERVICE			
1	Open and tag switch.		
2	Inspect visual condition of wiring. Look for evidence of overheating.		
3	Check for proper light operation.		
4	Test operation of automatic switches/ time clock/ photocells if applicable.		
5	Inspect light pole and mounting devices for deficiencies.		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

1 P

Right

Six

out

BK

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #:

P. 055 - 01


LOCATION/RM #:

NEP

WO# 10729

ASSET #

7428

MECHANIC
SIGNATURE:


DATE:

8/12/11

START TIME: 0630

FINISH TIME:

0635

SECTION INSTRUCTIONS		YES	NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		
2	Schedule and coordinate work with operating personnel.		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		
TO BE PERFORMED BY A QUALIFIED SERVICE PERSONNEL			
1	Open and tag switch.		
2	Inspect visual condition of wiring. Look for evidence of overheating.		
3	Check for proper light operation.		
4	Test operation of automatic switches/ time clock/ photocells if applicable.		
5	Inspect light pole and mounting devices for deficiencies.		
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by General Maintenance Worker

Additional Notes:

1 P. BK