

Date: 4-24-25

Region: 4A

FEMS/CSS No.: 3114312

FAC ID: PA062

Maximo WO No.: 18802

Asset #:

Priority:  3



**Original Work Request:**

Repair light fixtures in storage caging. During Industrial Hygiene assessment the lighting in the storage room caging did not meet E385 1-1 safety standards. The minimum requirement is 25 foot candles and the present ones are 18 fc. There are 8 LED fixtures with 2 tubes each. After light fixtures are repaired we will need a light meter reading to ensure we meet the 25 FC in the storage area.

**Description of Repairs Needed:**

Replace LED light kits in storage caging and ensure 25 FC requirement is met.

**Labor:**

	Labor Hrs	Labor Rate	Total
Tech (2)	9	\$ 100.00	\$ 900.00
			\$ -
			\$ -

**Material List:**

	Quantity	Cost	Total
2x4 ft LED Retrofit kit, 36W, 5400LM, daylight white, 5000K	10	\$ 39.99	\$ 399.90
Misc materials (wire nuts, tape, shop supplies...)	1	\$ 50.00	\$ 50.00
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

**Equipment List:**

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	

**PM WO History:**


**Estimate Summary:**

Labor	Material	Equipment
\$900.00	\$449.90	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$1,349.90	\$161.99	\$80.99	\$1,592.88