

Date: 12-2-25



Region: 4A

FEMS/CSS No.: 3265673

FAC ID: PA063

Maximo WO No.: 20738

Asset #:

Priority: 2

Original Work Request:

During the annual fire system inspectin four batteries failed the load test. Two 12v 75AH are needed for the OMS NACP panel and two 12v 75AH for the OMS Mass notification panel.

Description of Repairs Needed:

Replacement of four bad batteries on the fire system at USARC New Castle (PA063).

Labor:	Labor Hrs	Labor Rate	Total
Tech (1)	2	\$ 170.00	\$ 340.00
Trip	1	\$ 50.00	\$ 50.00
Tech (1)	4	\$ 170.00	\$ 680.00
Trip	1	\$ 50.00	\$ 50.00

Material List:	Quantity	Cost	Total
12v 75AH batteries	4	\$ 350.00	\$ 1,400.00
freight	1	\$ 60.00	\$ 60.00
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$1,120.00	\$1,460.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$2,580.00	\$309.60	\$154.80	\$3,044.40