

Date: 10-18-23

Region: 4A
FAC ID: PA027

CSS No.: 95207
Maximo WO No.: 14083

Asset #:

Priority: 3



Original Work Request:

Repair the remote emergency stop button for the boilers. Recommended contractor: Renick Brothers

Description of Repairs Needed:

Investigate issue to repair emergency stop button for boilers and replace the emergency stops on the Munchkin Boilers at USARC Farrell (PA027). All materials are in stock

Labor:

	Labor Hrs	Labor Rate	Total
Tech (1) - Initial Investigation	1.5	\$ 148.00	\$ 222.00
Tech (1) - Repair	8	\$ 148.00	\$ 1,184.00

Material List:

	Quantity	Cost	Total
Initial Investigation Fuel Charge	1	\$ 76.00	\$ 76.00
Intital Investigation Truck Fee	1	\$ 50.00	\$ 50.00
Repair- Electrical (wiring, junction box, relay coils, etc.	1	\$ 800.00	\$ 800.00
Repair- Emergency Stop	1	\$ 16.00	\$ 16.00
Repair- Fuel Charge	1	\$ 76.00	\$ 76.00
Repair- Truck Fee	1	\$ 50.00	\$ 50.00
			\$ -

Equipment List:

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$1,406.00	\$1,068.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$2,474.00	\$296.88	\$148.44	\$2,919.32