

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
VEHICLE EXHAUST REMOVAL

SITE AND BLDG #:

Pr 079-02

MECHANIC
SIGNATURE:

DATE:

8/26/18

LOCATION/RM #:

WO# 10853

ASSET # 859

START TIME:

FINISH TIME:

CHECKLIST NUMBER	CHECKLIST DESCRIPTION	SPECIAL INSTRUCTIONS	TASK FOR PERIOD		NOTES/ACCOMPLISHMENTS (UDR/COMPLIANCE/RECOMMENDATION)
			YRS.	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.				
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
1	Start and stop fan with local switch	TO BE PERFORMED AT EACH INSPECTION SERVICE			
2	Check motor and fan shaft bearings for noise, vibration, overheating; lubricate bearings.				
3	Inspect, adjust belts and pulleys. Replace belt as needed.				
4	Clean dampers; lubricate pivot points (annually) and inspect linkages for tightness.				
5	Inspect fan for bent blades, unbalance, excessive noise and vibration.				
6	Clean fan as needed.				
7	Visually inspect exhaust system tubing and/or duct work for any damage that could result in leaks.				
8	Repair as needed				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

1 Pr

Does Not Exist Right Not

BL