

Renick Brothers Construction Co.

PO Box 94 434 Grove City Road

Slippery Rock PA 16057

Tele 724-794-4200 Fax 724-794-8811

**Labor and Equipment Daily Record for:
Time and Material Basis Contracts**

This record is to be signed daily by the Representative of Renick Brothers, and the client on all time and material contracts.

Project Name: USARC Connect Date 2-20-23 Sheet Number: 1 Shift: 1

Renick Project/Work Order Number: 50576

Definitions: **Division**
* PM - Project Manager
SF - Steamfitter
PF - Pipefitter (354)
SM - Sheet Metal
PL - Plumber

- * **Labor Classification**
- * SUP- Superintendent
- GF - General Foreman
- Fore - Foreman
- JY - Journeyman
- Lab - Common Laborer

- * Del - Delivery Driver
- Ware - Warehouse Foreman
- * Tech - Service Technician

* Renick Brothers will charge mileage port to port.

DESCRIPTION OF WORK PERFORMED TODAY

RENICK OWNED EQUIPMENT USED

Removed both repair pieces from sewage pipe. Cap Both ends and pressure test to 4 psi. Air bubbles surfaced through ground between vault and road. Replaced both repair pieces and informed Scott. Send Video to Scott.

Client Approval

Data

Banker Approval

Date

Copy Distribution: WHITE (Foreman/Return to office weekly) YELLOW (Client) PINK (Foreman)

Rev. 8/2020

Service Items

Name	Description	Tier 1 Price	Unit Type	QTY	Taxable
Labor	See attached pages for details of work performed.	\$0.00	Hour	1	N
TOTAL*:	\$0.00				

* Not including taxes



Service Forms

Daily Form	Fill out every day, even on PMs, and projects
TECH NAME	Tim Diamond
DATE	2/20/23
TOOLS USED	handtools
MATERIALS USED	see Jesse Miller
DESCRIPTION OF WORK PERFORMED	assisted Jesse with pressure testing sewer line and replacing pipe we took out to pressure test
HOURS	REGULAR: 8
	OVERTIME:



Attachments

Service Items

Name	Description	Tier 1 Price	Unit Type	QTY	Taxable
Labor	See attached pages for details of work performed.	\$0.00	Hour	1	N
TOTAL*:	\$0.00				

* Not including taxes

Service Forms

Daily Form Fill out every day, even on PMs, and projects
TECH NAME Ethan Mcelroy
DATE 2/20/23
TOOLS USED hand tools
MATERIALS USED w/ Tim Diamond
DESCRIPTION OF WORK PERFORMED air tested line for leak
HOURS REGULAR:8
OVERTIME:

Attachments