

Date: 2-11-26



Region: 4A

FEMS/CSS No.: 3462495

FAC ID: PA118

Maximo WO No.: 21192

Asset #:

Priority: 2

Original Work Request:

The overhead crane in the high bay suddenly stopped working. It has power but seems frozen and will not move when the remote buttons are pressed

Description of Repairs Needed:

Proposal is to investigate repair needs for crane and provide repair quote. Crane has temporarily been returned to operation, but will need to have the brake assembly replaced for permanent repair. Once ordered, the brake assembly has a 4-6 week lead time.

Labor:

	Labor Hrs	Labor Rate	Total
Tech (2) - Investigation	16	\$ 103.13	\$ 1,650.00
Tech (2) - Repair	16	\$ 156.25	\$ 2,500.00
			\$ -

Material List:

	Quantity	Cost	Total
Brake Assembly (385366Q)	1	\$ 933.33	\$ 933.33
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:

	Quantity	Cost	Total
Lift Rental - Investigation	1	\$ 850.00	\$ 850.00
Lift Rental - Repair	1	\$ 850.00	\$ 850.00
			\$ -

PM WO History:

--

Estimate Summary:

Labor	Material	Equipment
\$4,150.00	\$933.33	\$1,700.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$6,783.33	\$814.00	\$407.00	\$8,004.33