

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #:

Pc 183

LOCATION/RM #:

Pcher

WO#

10872

ASSET #

7363

MECHANIC

SIGNATURE:

[Signature]

DATE:

9/17/10

START TIME:

1:40

FINISH TIME:

11:15

GENERAL INSTRUCTIONS		SPECIAL INSTRUCTIONS		NOTES/REMARKS	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Schedule and coordinate work with operating personnel.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Open and tag switch.				
2	Inspect visual condition of wiring. Look for evidence of overheating.				
3	Check for proper light operation.				
4	Test operation of automatic switches/ time clock/ photocells if applicable.				
5	Inspect light pole and mounting devices for deficiencies.				
6	For any noted deficiency, takes pictures and open corrective maintenance ticket.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

1 Pc

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #:

Pa 193

LOCATION/RM #:

Hotel

WO#

16922

ASSET #

7324

MECHANIC

SIGNATURE:

T. G. e

DATE:

9/6/18

START TIME:

10:00

FINISH TIME:

11:00

GENERAL INSTRUCTIONS		TO BE PERFORMED AT EACH INSPECTION SERVICE	
NO.	DESCRIPTION	YES	NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		
2	Schedule and coordinate work with operating personnel.		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		
1	Open and tag switch.		
2	Inspect visual condition of wiring. Look for evidence of overheating.		
3	Check for proper light operation.		
4	Test operation of automatic switches/ time clock/ photocells if applicable.		
5	Inspect light pole and mounting devices for deficiencies.		
6	For any noted deficiency, take pictures and open corrective maintenance ticket.		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

1 Pa 4 Item

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST LIGHTING, OUTSIDE

SITE AND BLDG #:

Pk 192

LOCATION/RM #:

Park

WO# *10877*

ASSET # *7395*

MECHANIC
SIGNATURE:

[Signature]

DATE:

8/10/14

START TIME:

1040

FINISH TIME:

11:14

GENERAL INSTRUCTIONS		SPECIAL INSTRUCTIONS		COMMENTS	
NO.	DESCRIPTION	YES	NO	YES	NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.				
2	Schedule and coordinate work with operating personnel.				
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.				
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Open and tag switch.				
2	Inspect visual condition of wiring. Look for evidence of overheating.				
3	Check for proper light operation.				
4	Test operation of automatic switches/ time clock/ photocells if applicable.				
5	Inspect light pole and mounting devices for deficiencies.				
6	For any noted deficiency, take pictures and open corrective maintenance ticket.				

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

4 P-