

Date: 2-5-26



Region: 4A

FEMS/CSS No.: 3497097

FAC ID: PA209

Maximo WO No.: 21211

Asset #:

Priority: 2

Original Work Request:

Repair by replacement circulation pump #2 as it is seized up and will no longer work

Description of Repairs Needed:

Proposal is to replace circulation pump #2 then startup and check for proper operation.

Labor:	Labor Hrs	Labor Rate	Total
Tech (2) - Initial Investigation	14	\$ 170.00	\$ 2,380.00
Trip Charge	1	\$ 180.00	\$ 180.00
Tech (2) - Repair	16	\$ 170.00	\$ 2,720.00
Trip Charge	1	\$ 180.00	\$ 180.00

Material List:	Quantity	Cost	Total
Circulating Pump (3D-4360)	1	\$ 6,110.00	\$ 6,110.00
Circulating Pump Gaskets (GSKT-1030)	1	\$ 32.00	\$ 32.00
Freight	1	\$ 250.00	\$ 250.00
			\$ -
			\$ -
			\$ -
			\$ -

Equipment List:	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

Estimate Summary:

Labor	Material	Equipment
\$5,460.00	\$6,392.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$11,852.00	\$1,422.24	\$711.12	\$13,985.36