

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST **VAULT DOOR**

SITE AND BLDG #: PA209-01

MECHANIC

SIGNATURE: Elin TaylorDATE: 7/25/19LOCATION/RM #: _____ WO# 9788 ASSET # 7929START TIME: 1015FINISH TIME: 11:00

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO. PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.	✓		
2	Review manufacturer's instructions.	✓		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check alignment of dial ring with lock case; correct if necessary.	✓		
2	Check mounting screws of dial ring and lock case; tighten them, using a thread locking compound.	✓		
3	Look for corrosion or presence of any foreign matter that will in any manner affect the lock's proper operation.	✓		
4	Look for any signs of malfunctioning or impending failure.	✓		
5	Look for any signs of tampering, forced, or covert entry; report this to the local Security and Law Enforcement Office.	✓		
6	Check Alignment of door with frame	✓		
7	Check for difficulty in opening, closing or locking the door.	✓		
8	Replace all defective hardware	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

1. A qualified locksmith with expertise in GSA locks is required.

2. Prior Coordination with the facility must occur prior to scheduled work. (See suggested coordination questions below)

a. Access to Arms room is accompanied. Someone with unaccompanied access MUST be present at all times during scheduled work.

b. Coordination AND approval from the Facility Coordinator or Physical Security Officer or PIN Custodian for combination change.

Additional Notes:

No problems found