

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**UNIT HEATER, INFRA-RED, RADIANT, GAS**

SITE AND BLDG #: NY051-2 Oswego

MECHANIC  
SIGNATURE: 

DATE: 6/23/23

LOCATION/RM #: OMS WO# 22495 ASSET # PM-SA-10075

START TIME: 1258

FINISH TIME: 1320

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	X		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	For gsa/oil heaters: 1. Remove access panels if applicable. 2. Check the fire box liner or refractory for cracks and leaks. 3. Check all gas lines for leaks. Repair as needed.	X		
2	Clean dirt from heater, vaccuming is preferred.	X		
3	Check operation of gas valve.	X		
4	Check for gas leaks.	X		
5	Check operation of thermostat.	X		
6	If applicable, replace primary air intake filter.	X		
7	As needed, clean spark electrode and reset gap, replace if necessary.	X		
8	Inspect flue pipe and connections.	X		
9	If applicable, inspect and clean outside air blower and blower intake.	X		
10	Inspect unit for proper operation.	X		
11	Inspect unit for overall condition and recommend for replacement or other needed repairs.	X		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

**Additional Notes:**