



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Christiansburg, VA

Falmouth, VA • Lynchburg, VA • Richmond, VA • Greensboro, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address	Site Address
Customer: INTERNATIONAL SUPPORT GROUP Address: 9000 SHERIDAN ST PEMBROKE PINES FL 33024 Phone: 954-900-1095	Customer: ISG USARC VA048 RICHMOND Address: 1741 EAST BELT BOULEVARD RICHMOND VA 23224 Phone:
Service Call #: COM0116313	Call Type: COM-PM

Service Requested

SEPTEMBER PM
PM FOR HVAC

THIS IS A TIME AND MATERIAL PM, SO THERE ARE NO SPECIFIC HRS.

SEE CODE 35 FORM FOR HOW MANY PIECES ARE ON SITE TO PM. EX-10100 1599 PM-QT-1599 J-1502000-27 1-pc Water Heater Break Room (THERE IS 1
PIECE OF EQUIP)
CODE 35 AND COW

ANY ADDITIONAL WORK NEEDED OUTSIDE THE SCOPE ON THE FORM, PLEASE TAKE PHOTOS, DOCUMENT IN SERVICE NOTES, AND SUBMIT A QUOTE.

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
Commercial Planned Maintenance	PETELANGST	ALL HVAC UNITS	Generic		

Tech Notes

Site Start - 9/25/2019 8:00 AM Site Stop - 9/25/2019 12:00 PM CHANGED FILTERS AND CLEANED FILTERS ON HVAC UNITS. FOUND ONE UNIT WITH A BAD
BELT AND A SPARE WAS ON SITE AND INSTALLED BELT. COMPLETED TASKING FORM.

Labor

Date	Technician	Description	Hours
9/25/2019	Peter Langston	REGULAR HVACR LABOR	1.00
9/25/2019	Thomas Sandlin	REGULAR HVACR LABOR	4.00

Materials

Date	Part Number	Description	Quantity
9/10/2019	CMISCX-NON-STOCK ITEM	16X25X1 FILTER	8.000
9/10/2019	TAX-S	Sales Tax for Service	1.000
9/25/2019	CMISCX-NON-STOCK ITEM	Items for PO 207019	1.000

Signed By	Major Drakes	Signature		Date	9/26/2019
-----------	--------------	-----------	--	------	-----------