



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Christiansburg, VA

Falmouth, VA • Lynchburg, VA • Richmond, VA • Greensboro, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address	Site Address
Customer: INTERNATIONAL SUPPORT GROUP Address: 9000 SHERIDAN ST Phone: PEMBROKE PINES FL 33024 954-900-1095	Customer: ISG USARC VA099 BEDFORD Address: 1117 HARMONY LANE Phone: BEDFORD VA 24523 8045855211
Service Call #: COM0116482	Call Type: COM-PM

Service Requested

SEPTEMBER PM
PM FOR UNIT HEATER ELECTRIC
THIS IS A TIME AND MATERIAL PM, SO THERE ARE NO SPECIFIC HRS.
SEE CODE 35 FORM FOR HOW MANY PIECES ARE ON SITE TO PM. EX-10100 1599 PM-QT-1599 J-1502000-27 1-pc Water Heater Break Room (THERE IS 1
PIECE OF EQUIP)
CODE 35 AND COW
ANY ADDITIONAL WORK NEEDED OUTSIDE THE SCOPE ON THE FORM, PLEASE TAKE PHOTOS, DOCUMENT IN SERVICE NOTES, AND SUBMIT A QUOTE.

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
Commercial Planned Maintenance	TYSONBELL	ELECTRIC HEATERS BUILDING #2	Trane	NONE NEEDED	

Tech Notes

Tech: BRANDON HAROLD: Site Start - 9/16/2019 8:30 AM

Drove to site, checked in with Huson, and set up at building #2. Inspected electric heaters, dusted heat strips, dusted all fan blades, inspected electrical wiring, verified operations, and completed customer task form. No problems found at this time. PM complete.

Tech: BRANDON HAROLD: Site Stop - 9/16/2019 12:30 PM

Labor

Date	Technician	Description	Hours
9/16/2019	BRANDON HAROLD	REGULAR HVACR LABOR	4.00

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	Malachi Caesar	Signature		Date	9/17/2019