



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Christiansburg, VA

Falmouth, VA • Lynchburg, VA • Richmond, VA • Greensboro, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address	Site Address
Customer: INTERNATIONAL SUPPORT GROUP Address: 9000 SHERIDAN ST Phone: PEMBROKE PINES FL 33024 954-900-1095	Customer: ISG USARC VA099 BEDFORD Address: 1117 HARMONY LANE Phone: BEDFORD VA 24523 8045855211
Service Call #: COM0116487	Call Type: COM-PM

Service Requested

SEPTEMBER PM
PM FOR UNIT HEATER
THIS IS A TIME AND MATERIAL PM, SO THERE ARE NO SPECIFIC HRS.
SEE CODE 35 FORM FOR HOW MANY PIECES ARE ON SITE TO PM. EX-10100 1599 PM-QT-1599 J-1502000-27 1-pc Water Heater Break Room (THERE IS 1
PIECE OF EQUIP)
CODE 35 AND COW
ANY ADDITIONAL WORK NEEDED OUTSIDE THE SCOPE ON THE FORM, PLEASE TAKE PHOTOS, DOCUMENT IN SERVICE NOTES, AND SUBMIT A QUOTE.

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
Commercial Planned Maintenance	TYSONBELL	BUILDING #1 ELECTRICAL ROOM HEATER (M: UHEC-033DACA)	Trane	60721-016	

Tech Notes

Tech: BRANDON HAROLD: Site Start - 9/17/2019 12:00 PM

Set up in the Electrical Room at the electric heater. Powered the system down, brushed coils, cleaned the fan blade, powered the system on, verified operations, and completed customer task form. No problems found. PM complete.

Tech: BRANDON HAROLD: Site Stop - 9/17/2019 12:30 PM

Labor

Date	Technician	Description	Hours
9/17/2019	BRANDON HAROLD	REGULAR HVACR LABOR	0.50

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	Malachi Caesar	Signature		Date	9/17/2019