



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Christiansburg, VA

Falmouth, VA • Lynchburg, VA • Richmond, VA • Greensboro, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreselectric.com

Billing Address	Site Address
Customer: INTERNATIONAL SUPPORT GROUP Address: 9000 SHERIDAN ST Phone: PEMBROKE PINES FL 33024 954-900-1095	Customer: ISG USARC VA048 RICHMOND Address: 1741 EAST BELT BOULEVARD Phone: RICHMOND VA 23224
Service Call #: COM0115542	Call Type: COM-PM

Service Requested

PM FOR HVAC UNITS

THIS IS A TIME AND MATERIAL PM, SO THERE ARE NO SPECIFIC HRS.

THERE ARE 5 PIECES OF EQUIPMENT, LISTED ON THE FORM.

CODE 35,6

ANY ADDITIONAL WORK NEEDED OUTSIDE THE SCOPE ON THE FORM, PLEASE TAKE PHOTOS, DOCUMENT IN SERVICE NOTES, AND SUBMIT A QUOTE.

9654 2284 FQ-2284 J-1502000-04 1-pc AC Unit, Wall Unit

9654 2285 FQ-2284 J-1502000-04 1-pc Air Handler

9654 2286 FQ-2284 J-1502000-04 1-pc Air Handler

9654 2287 FQ-2284 J-1502000-04 1-pc Air Handler,Inoperable

9654 2288 FQ-2284 J-1502000-04 1-pc Air Handler,Inoperable

Problems

Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
Commercial Planned Maintenance	ALANBOLING				

Tech Notes

Tech: ALAN BOLING, Date: 8/26/19 Arrived on site, checked in with Mr. Scott Grenier (regional facility operations specialist). Mr. Scott escorted us(my ASM) around site to locate equipment listed for PM, which we all could not find. Many units have asset numbers missing or numbers faded. All office spaces have PTAC units and hallways have mini splits. Was able to locate water heater for main building and another in motor pool area. (will pm those on another ticket). Did find multiple units not operating properly. XO of site pointed out units in conference room(2 ptacs)(room number 202) not operating properly during peak temps. Also pointed to site commander office ptac (room number 206) not operating at all. Also went to motor pool to find if equipment listed for PM was there, but as said above, asset numbers were faded off. Motor pool SGT, did state all(3) mini splits and AHU in motor pool is not operating properly at all. He stated he put in an emergency call, but I stated we were only there to PM listed equipment.

*Please note, even being escorted by facility operations specialist, unable to find listed equipment listed in filter replacement PM.

Labor

Date	Technician	Description	Hours
8/26/2019	ALAN BOLING	COMMERCIAL TRAVEL TIME	1.50
8/26/2019	Jerome Lott	COMMERCIAL TRAVEL TIME	1.50
8/26/2019	Jerome Lott	REGULAR HVACR LABOR	1.50
8/26/2019	ALAN BOLING	REGULAR HVACR LABOR	1.50

Materials

Date	Part Number	Description	Quantity
No records found			

Signed By	N/A	Signature		Date	8/26/2019
-----------	-----	-----------	--	------	-----------