

Date: 6/27/2023

Region: 4A  
FAC ID: NY126

CSS No.: 93738  
Maximo WO No.: 13030

Asset #: 3221

Priority: Emergency



**Original Work Request:**

Repair chiller. Chiller is in alarm and will not operate.

**Description of Repairs Needed:**

Labor and material to a.) recharge the system with R410A refrigerant (25 lbs)

**Labor:**

	Labor Hrs	Labor Rate	Total
Technician	5.25	\$ 115.00	\$ 603.75
			\$ -

**Material List:**

	Quantity	Cost	Total
R410A 25 LBS	1	\$ 770.01	\$ 770.01
Oil	1	\$ 240.83	\$ 240.83
Trip fee	1	\$ 98.00	\$ 98.00
		\$	-
		\$	-
		\$	-

**Equipment List:**

	Quantity	Cost	Total
		\$	-
		\$	-
		\$	-

**PM WO History:**

12682

**Estimate Summary:**

Labor	Material	Equipment
\$603.75	\$1,108.84	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$1,712.59	\$205.51	\$102.76	\$2,020.86