

Date: 7/20/2023

Region: 4C  
FAC ID: WV020

CSS No.: 94296  
Maximo WO No.: 13424

Asset #: G224

Priority: Routine



**Original Work Request:**

Repair fire alarm system in Training building. Alarm going off constantly & cant silence it. Code reads: power supply & battery charger.

**Description of Repairs Needed:**

Labor to a.) troubleshoot Power Supply and battery issue on the Fire Panel

**Labor:**

	Labor Hrs	Labor Rate	Total
Technician	5	\$ 100.00	\$ 500.00
			\$ -

**Material List:**

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	
		\$ -	
		\$ -	
		\$ -	

**Equipment List:**

	Quantity	Cost	Total
		\$ -	
		\$ -	
		\$ -	


**PM WO History:**

13324

**Estimate Summary:**

Labor	Material	Equipment
\$500.00	\$0.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$500.00	\$60.00	\$30.00	\$590.00



## SERVICE QUOTE

QUOTE NO.	QUOTE DATE	EXPIRATION
8982	7/18/2023	8/16/2023

**To:** Tidewater, Inc.  
6625 Selnick Drive, Suite A  
SUBMIT ON PORTAL!!!!!!  
Elkridge, MD 21075  
(724) 678-6067  
karlee.deman@tideh20.net  
TIDEWATE

**Site:** USARC 99th - Jane Lew  
7605 US Rt 19 North  
Jane Lew, WV 26354  
(724) 544-5252  
USARCJL

**Brewer & Company is pleased to provide a quote for the following item(s):**

QTY	DESCRIPTION	UNIT PRICE	EXTENDED TOTAL
1	Trouble Shhoot Power Supply and battery issue on the Fire Panel	500.00	500.00

**TOTAL** **\$ 500.00**

- All sprinkler work shall be in accordance with NFPA 13 and WV State Fire Code. No shop drawings will be provided/required unless noted otherwise above.
- All alarm work shall be in accordance with NFPA 70, 72, and WV State Fire Code. No shop drawings will be provided/required unless noted otherwise above.
- All sprinkler inspections shall be in accordance with NFPA 25 and WV State Fire Code. All alarm inspections shall be in accordance with NFPA 72 and WV State Fire Code. All extinguisher inspections shall be in accordance with NFPA 10 and WV State Fire Code.
- Excluded work consists of shop drawings, hydraulic calculations, fire extinguishers, and fire watches unless noted otherwise above.
- All electrical work excluded unless noted otherwise above.
- All work quoted to be performed during normal working hours unless noted otherwise above.
- All applicable taxes are not included unless noted otherwise.
- All quotes are subject to credit approval and Brewer credit limits. A deposit may be required.
- Customer agrees to pay all costs of collection up to and including court costs, collection fees, attorney's fees of not less than 33% of unpaid principal and interest. Outstanding balances are subject to 2% per month interest charges.
- Size, brand, model and style of quoted equipment may be required after submission for approval to authority having jurisdiction (AHJ). Additional equipment which is not included in this quote is sometimes required by the AHJ, unforeseen circumstances or changes in scope or occupancy by the owner or AHJ. Additional required labor and material will be billed on a time and material basis.
- Delays or repeat trips as caused by the customer, customer's representative or site conditions may result in additional labor charges to be billed on a time and material basis.
- Please forward a copy of your WV Sales Tax Certificate or Direct Pay/Tax Exempt Form.

If you have any questions, please contact me.

Thank you,  
Casey Harbour  
[Casey.harbour@brewerfire.com](mailto:Casey.harbour@brewerfire.com)  
304-807-3566 cell

Approved by: \_\_\_\_\_

Signed: \_\_\_\_\_

Date: \_\_\_\_\_

PO: \_\_\_\_\_