

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
PTAC

SITE AND BLDG #: PA209

MECHANIC
SIGNATURE:

DATE: 4/10/2024

LOCATION/RM #: WO# 15340 ASSET # See notes START TIME: 10:00AM FINISH TIME: 3:30AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Schedule shutdown with operating personnel, as needed.	●	○	
2	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	●	○	 
TO BE PERFORMED AT EACH INSPECTION				
1	Clean the filter with a vacuum or running water. Inspecet filter quarterly, replace/clean as needed	●	○	
2	Remove the front grille and clean it with a dampened cloth.	●	○	
3	Inspect the control panel door and plug. Repair deficiencies.	●	○	
4	Check the caulking around the PTAC wall sleeve to make sure all air and water openings are properly sealed.	●	○	
5	Check that condensate drains properly. Remove any debris/blockages.	●	○	
6	Clean condenser coils with proper coil cleaner.	●	○	
7	Place drain pan cleaner tablet in the basepan to inhibit bacteria growth.	●	○	
8	Check clearance around the HVAC unit to ensure that the intake air and discharge air paths are not blocked or restricted	●	○	
9	Clean up work area.	●	○	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials). If the repair cost exceeds \$250, the technician shall open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: Asset3989,3990,3991,3992,3993,3994