

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**PTAC**

**SITE AND BLDG #:** NY051 BLDG2  
**BLDG2 office**  
**LOCATION/RM #:** WO# 21282    **ASSET #** 10077

**MECHANIC  
SIGNATURE:** 

**DATE:** 3/8/23

**START TIME:** 12:30pm

**FINISH TIME:** 12:45pm

<b>CHECK POINT</b>	<b>CHECKPOINT DESCRIPTION</b>	<b>TASK COMPLETE</b>		<b>NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</b>
		<b>YES</b>	<b>NO</b>	
<b>SPECIAL INSTRUCTIONS</b>				
1	Schedule shutdown with operating personnel, as needed.	✓		
2	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Clean the filter with a vacuum or running water. Inspecet filter quarterly, replace/clean as needed	✓		
2	Remove the front grille and clean it with a dampened cloth.	✓		
3	Inspect the control panel door and plug. Repair deficiencies.	✓		
4	Check the caulking around the PTAC wall sleeve to make sure all air and water openings are properly sealed.	✓		
5	Check that condensate drains properly. Remove any debris/blockages.	✓		
6	Clean condenser coils with proper coil cleaner.	✓		
7	Place drain pan cleaner tablet in the basepan to inhibit bacteria growth.	✓		
8	Check clearance around the HVAC unit to ensure that the intake air and discharge air paths are not blocked or restricted	✓		
9	Clean up work area.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be perfomed by: General Maintenance Worker

**Additional Notes:**