

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

Pr 017-01
 SITE AND BLDG #: **WO# 7888** ASSET # **5074**
 LOCATION/RM #:

MECHANIC
SIGNATURE:

START TIME:

Tom V. Johnson
 DATE: **3/21/19**
 920 FINISH TIME: **930**

CHECK ROUTINE	CHECKROUTINE DESCRIPTION	BASIC COMPLETION		NOTES/ACCTIONS (BASIC CHECKLIST CHECKED NO FURTHER ACTION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		/	
2	Schedule outage of unit with personnel in area the unit serves.	/		
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	/		
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.	/		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Remove debris from air screen and clean underneath unit.	/		
2	Wash coil with coil cleaning solution - Rinse Thoroughly	/		
3	Straighten fin tubes with fin comb, as needed.	/		
4	Check electrical connections for tightness.	/		
5	Check mounting base for tightness.	/		
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	/		
7	Inspect all piping for leaks and tighten loose connections.	/		
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	/		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.	/	Pla	Too Cool
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	/		
11	Clean up work area.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
OUTDOOR CONDENSING UNIT

SITE AND BLDG #:

P0017-01

LOCATION/RM #:

Law

WO# 7988

ASSET # 5025

MECHANIC
SIGNATURE:

START TIME:

930

DATE:

3/6/19

FINISH TIME:

990

CHECK ITEM	CHECK ITEM DESCRIPTION	BASIC COMPLETION		NOTES/ACTIONS (BASIC COMPLETION CHECKED NO PROBLEMS)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.		✓	
2	Schedule outage of unit with personnel in area the unit serves.		✓	
3	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
4	If disposal of the equipment is required, follow regulations concerning removal of refrigerants and disposal of the unit.		✓	
TASKS PERFORMED AT EACH INSPECTION SERVICE				
1	Remove debris from air screen and clean underneath unit.	✓		
2	Wash coil with coil cleaning solution - Rinse Thoroughly	✓		
3	Straighten fin tubes with fin comb, as needed.	✓		
4	Check electrical connections for tightness.	✓		
5	Check mounting base for tightness.	✓		
6	Inspect fans for bent blades, unbalance, excessive noise and vibrations.	✓		
7	Inspect all piping for leaks and tighten loose connections.	✓		
8	Check wires at condenser electrical fused safety switches for tightness and burned insulation. Repair as necessary.	✓		
9	Check supply air temperature to ensure unit is operating properly. If possible record room temperature.	✓	✓	C-11
10	Inspect unit for overall condition and recommend for replacement or other needed repairs.	✓		
11	Clean up work area.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: *P-017-01*LOCATION/RM #: *101*WO# *7988*ASSET # *5125*MECHANIC
SIGNATURE: *Paul W. Johnson*START TIME: *8/15*DATE: *3/21/19*FINISH TIME: *825*

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Schedule shutdown with operating personnel, as needed.	/		
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/		
1	Check fan blades for dust buildup and clean if necessary.		N/A	
2	When applicable, check fan blades and moving parts for cracks and excessive wear.		N/A	
3	Tighten all electrical connectors to proper torque as needed.			
4	Check that the fan runs properly in all speeds as applicable.			
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.			
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.			
7	Lubricate mechanical connections of dampers sparingly as applicable.		N/A	
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.		N/A	
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.			
10	Check coils for leaking, tightness of fittings.			
11	Use fin comb to straighten coil fins as needed.		N/A	

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: *Pt 012 - 01*
 LOCATION/RM #: *102* WO# *7988* ASSET # *5174*
 MECHANIC SIGNATURE: *John Johnson*
 DATE: *3/21/18*
 START TIME: *825*
 FINISH TIME: *835*

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Schedule shutdown with operating personnel, as needed.			
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/		
1	Check fan blades for dust buildup and clean if necessary.			
2	When applicable, check fan blades and moving parts for cracks and excessive wear.			
3	Tighten all electrical connectors to proper torque as needed.	/		
4	Check that the fan runs properly in all speeds as applicable.	/		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/		
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/		
7	Lubricate mechanical connections of dampers sparingly as applicable.			
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.			
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/		
10	Check coils for leaking, tightness of fittings.	/		
11	Use fin comb to straighten coil fins as needed.	/		

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary. *N/A*
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary. *N/A*
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: *Pr-017-01*LOCATION/RM #: *103* WO# *7988*ASSET # *5177*MECHANIC
SIGNATURE:
John

DATE:

3/21/19

START TIME:

835

FINISH TIME:

845

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓	
2	Schedule shutdown with operating personnel, as needed.		
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓	
4	Check fan blades for dust buildup and clean if necessary.		<i>P(1)</i>
5	When applicable, check fan blades and moving parts for cracks and excessive wear.		<i>P(1)</i>
6	Tighten all electrical connectors to proper torque as needed.	✓	
7	Check that the fan runs properly in all speeds as applicable.	✓	
8	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓	
9	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment. Lubricate mechanical connections of dampers sparingly as applicable.	✓	<i>AR</i> <i>P(1)</i>
10	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	✓	<i>P(1)</i>
11	Clean coils by brushing, blowing, vacuuming, or pressure washing.	✓	
12	Check coils for leaking, tightness of fittings.	✓	
13	Use fin comb to straighten coil fins as needed.	✓	<i>P(1)</i>

K00-046CMI Management Inc.

12. Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
13. Check rigid couplings for alignment on direct drives, and for tightness of assembly.
14. Vacuum interior of unit.
15. Check filter door for proper gasketing and air leaks. Correct as necessary.
16. Change the filter as needed with the correct size and type filter.
17. Insure that drain(s) are clear and running.
18. Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: Pa 017-41

LOCATION/RM #: 104

WO# 7988

ASSET # 5179

MECHANIC
SIGNATURE:

DATE:

3/21/19

START TIME:

845

FINISH TIME:

855

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
-------------	------------------------	------------------------------	---

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

N/A
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

✓
✓✓
✓✓
✓✓
✓✓
✓✓
✓

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: *PA 017 - 01*LOCATION/RM #: *109* WO# *7988*ASSET # *5181*MECHANIC
SIGNATURE:
John

START TIME:

855

DATE:

3/21/18

FINISH TIME:

905

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Schedule shutdown with operating personnel, as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
1	Check fan blades for dust buildup and clean if necessary.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	Tighten all electrical connectors to proper torque as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Check that the fan runs properly in all speeds as applicable.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
7	Lubricate mechanical connections of dampers sparingly as applicable.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
10	Check coils for leaking, tightness of fittings.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11	Use fin comb to straighten coil fins as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: *P2017-01*LOCATION/RM #: *112* WO# *7989*ASSET # *5183*MECHANIC
SIGNATURE:
John

DATE:

*3/21/19*START TIME: *905*FINISH TIME: *915*

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.			
2	Schedule shutdown with operating personnel, as needed.			
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.			
1	Check fan blades for dust buildup and clean if necessary.			
2	When applicable, check fan blades and moving parts for cracks and excessive wear.			
3	Tighten all electrical connectors to proper torque as needed.			
4	Check that the fan runs properly in all speeds as applicable.			
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.			
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.			
7	Lubricate mechanical connections of dampers sparingly as applicable.			
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.			
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.			
10	Check coils for leaking, tightness of fittings.			
11	Use fin comb to straighten coil fins as needed.			

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: Pa 017-41
 LOCATION/RM #: 113 WO# 7988 ASSET # 5186
 MECHANIC SIGNATURE: *John H. Johnson*
 DATE: 3/2/19
 START TIME: 905 FINISH TIME: 925

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel, as needed.	✓		
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
1	Check fan blades for dust buildup and clean if necessary.	✓		✓
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	✓		✓
3	Tighten all electrical connectors to proper torque as needed.	✓		
4	Check that the fan runs properly in all speeds as applicable.	✓		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓		
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	✓		
7	Lubricate mechanical connections of dampers sparingly as applicable.	✓		
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	✓		✓
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	✓		✓
10	Check coils for leaking, tightness of fittings.	✓		
11	Use fin comb to straighten coil fins as needed.	✓		✓

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: *Pr 012-01*
 LOCATION/RM #: *220* WO# *7988* ASSET # *5192*
 MECHANIC SIGNATURE: *John A. Johnson*
 DATE: *3/2/19*
 START TIME: *925* FINISH TIME: *935*

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Schedule shutdown with operating personnel, as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
1	Check fan blades for dust buildup and clean if necessary.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>PL</i>
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>PL</i>
3	Tighten all electrical connectors to proper torque as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4	Check that the fan runs properly in all speeds as applicable.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
7	Lubricate mechanical connections of dampers sparingly as applicable.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>PL</i>
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>PL</i>
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>PL</i>
10	Check coils for leaking, tightness of fittings.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
11	Use fin comb to straighten coil fins as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>PL</i>

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes: