

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #:

Pr 017 -01

MECHANIC
SIGNATURE:


DATE:

9/11/18

LOCATION/RM #:

101

WO# 10942

ASSET # 5175

START TIME:

800

FINISH TIME:

805

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.
Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

NP
NP

/ / / / / / / / / / / /

NP

NP

NP

NP

NP

NP

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

NP

/ / / / / / / / / / / /

NP

NP

NP

NP

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
 To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT / DUCTLESS MINI SPLIT

SITE AND BLDG #: FA 877 -01

MECHANIC
SIGNATURE:

START TIME:

DATE:

LOCATION/RM #: 109

WO# 10992

ASSET # 5176

805

26.18

810

FINISH TIME:

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	START TIME:	FINISH TIME:
			NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Schedule shutdown with operating personnel, as needed.	/		
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/		
1	Check fan blades for dust buildup and clean if necessary.	✓		
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	✓		
3	Tighten all electrical connectors to proper torque as needed.	✓		
4	Check that the fan runs properly in all speeds as applicable.	✓		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓		
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	✓		
7	Lubricate mechanical connections of dampers sparingly as applicable.	✓		
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	✓		
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	✓		
10	Check coils for leaking, tightness of fittings.	✓		
11	Use fin comb to straighten coil fins as needed.	✓		

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: PR 012-01

MECHANIC
SIGNATURE:
START TIME:

LOCATION/RM #: 103

WO# 10942

ASSET # 5177

DATE:

9/11/19

FINISH TIME:

815

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
-------------	------------------------	------------------------------	---

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

✓
✓
✓
✓
✓
✓
✓
✓
✓
✓
✓
✓

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Worker
Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: *PP 017 - 01*MECHANIC
SIGNATURE:
John Taylor

START TIME:

DATE:

LOCATION/RM #: *104*WO# *10892*ASSET # *5179*

8:15

8/11/19

FINISH TIME: *8:20*

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
-------------	------------------------	------------------------------	---

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to. *✓*
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary. *✓*
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear. *✓*
- 3 Tighten all electrical connectors to proper torque as needed. *✓*
- 4 Check that the fan runs properly in all speeds as applicable. *✓*
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary. *✓*
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment. *✓*
- 7 Lubricate mechanical connections of dampers sparingly as applicable. *✓*
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE. *✓*
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing. *✓*
- 10 Check coils for leaking, tightness of fittings. *✓*
- 11 Use fin comb to straighten coil fins as needed. *✓*

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary. *✓*
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly. *✓*
- 14 Vacuum interior of unit. *✓*
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary. *✓*
- 16 Change the filter as needed with the correct size and type filter. *✓*
- 17 Insure that drain(s) are clear and running. *✓*
- 18 Clean up work area. *✓*


Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: Pa 012-01

LOCATION/RM #: 109 WO# 10842

ASSET # 5181

MECHANIC
SIGNATURE:


START TIME: 8:15

DATE: 8/1/19

FINISH TIME: 8:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST FAN COIL UNIT / DUCTLESS MINI SPLIT

SITE AND BLDG #:

P_A 012 -01

MECHANIC
SIGNATURE:

START TIME

DATE:

LOCATION/RM #: 115

115 WO# 10902

ASSET # 5183

860, 1, 9

LOCATION/RM #: 115 WO# 10942 ASSET # 5183 SIGNATURE: DATE: 8/11/19
START TIME: 820 FINISH TIME: 825
CHECK

FINISH TIME:

828

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	START TIME:	FINISH TIME:
			NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	✓		
2	Schedule shutdown with operating personnel, as needed.	✓		
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	✓		
1	Check fan blades for dust buildup and clean if necessary.	✓		
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	✓		
3	Tighten all electrical connectors to proper torque as needed.	✓		
4	Check that the fan runs properly in all speeds as applicable.	✓		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	✓		
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	✓		
7	Lubricate mechanical connections of dampers sparingly as applicable.	✓		
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	✓		
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	✓		
10	Check coils for leaking, tightness of fittings.	✓		
11	Use fin comb to straighten coil fins as needed.	✓		

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. For To be performed by: General Maintenance Worker
Additional Notes:

