

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 - 01

MECHANIC

SIGNATURE:

Mary Butze

DATE:

4/9/19

LOCATION/RM #:

114

WO#

8244

ASSET #

5487

START TIME:

0820

FINISH TIME:

0830

CHECK POINT	CHECKPOINT DESCRIPTION	PASS/COMPLETE		NOTES/ACTIONS (If task is completed, check box and provide explanation)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		/	
2	Review all zone set points at the server.		/	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set 73

ACUAC 68

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 -01

MECHANIC

SIGNATURE: *Harry Butz*

DATE:

4/8/18

LOCATION/RM #:

113

WO#

8244

ASSET #

5488

START TIME:

0830

FINISH TIME:

0940

CHECK POINT	DESCRIPTION	PASS/COMPLETE		NOTES/ACTIONS
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION/SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		NI	
2	Review all zone set points at the server.		NI	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.			
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

See 80

ACRAC 74

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 -01

MECHANIC
SIGNATURE:

May Berts

DATE:

4/8/19

LOCATION/RM #:

121

WO#

8244

ASSET #

5493

START TIME:

084

FINISH TIME:

085

CHECK NO.	CHECKPOINT DESCRIPTION	PASS/COMPLIANCE		NOTES/ACTIONS
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		ph	
2	Review all zone set points at the server.		ph	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.		ph	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Ser

Actune

Sensor

71

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 -01

MECHANIC
SIGNATURE:

Amy Butz

DATE:

4/9/19

LOCATION/RM #:

Hall B1
115

WO#

8249

ASSET #

5494

START TIME:

0900

FINISH TIME:

1000

CHECK POINT	CHECKPOINT DESCRIPTION	PASS/COMPLY/RE		NOTES/ACTIONS (If task is completed, check box and provide explanation)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		✓	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
TO BE PERFORMED AT EACH INSPECTION/SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		pln	
2	Review all zone set points at the server.		pln	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	✓		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	✓		
6	If applicable, replace battery as needed.		pln	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set

Gr

Acme

74

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050-01

MECHANIC

SIGNATURE:

Gary Butze

DATE:

4/9/19

LOCATION/RM #:

Broom WO# 8244 ASSET # 5524

START TIME:

1000

FINISH TIME:

1040

CHECKS (POINTS)	CHECK/DESCRIPTION	PASS/COMPLIANT		NOTES/ACTIONS
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.			
2	Review all zone set points at the server.			PLA
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.			PLA
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.			
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.			
6	If applicable, replace battery as needed.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set

GR

Actual 24

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050-01

MECHANIC

SIGNATURE:

Gary Betch

DATE:

4/9/19

LOCATION/RM #:

HACC B7
Barber Room

WO# 8244

ASSET #

5612

START TIME:

1010

FINISH TIME:

1020

CHECK POINT	CHECKPOINT DESCRIPTION	PASS/COMPLIANCE		NOTES/ACTIONS (If not completed, provide explanation)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		✓	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		PLA	
2	Review all zone set points at the server.		PLA	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	✓		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	✓		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	✓		
6	If applicable, replace battery as needed.		PLA	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Ser 72

Actual 73


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050-01

MECHANIC

SIGNATURE:



DATE:

4/2/18

LOCATION/RM #:

Boiler Room

WO# 8244

ASSET #

5747

START TIME:

1:25

FINISH TIME:

6:30

CHECKS (CIRCLE)	CHECK/DESCRIPTION	DATE COMPLETED		NOTES/ACTIONS (IF NECESSARY, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION/SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		N/A	
2	Review all zone set points at the server.		N/A	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.		/	
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.		/	
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.		/	
6	If applicable, replace battery as needed.		N/A	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

See

Account

Season

EC

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050-01

MECHANIC

SIGNATURE:

Harry Bojko

DATE:

4/9/19

LOCATION/RM #:

Hvac By Storage

WO# 8244

ASSET #

5896

START TIME:

1030

FINISH TIME:

1000

CHECK POINT	CHECKPOINT DESCRIPTION	PASS/COMPLIANCE		NOTES/ACTIONS (If not completed, provide explanation)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		nlr	
2	Review all zone set points at the server.		nlr	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.	/	nlr	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set 60

Acorn 73

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 -01

MECHANIC

SIGNATURE:

Mary Betz

DATE:

4/9/19

LOCATION/RM #:

104

WO#

8244

ASSET #

5897

START TIME:

1045

FINISH TIME:

1055

CHECK POINT		CHECKPOINT DESCRIPTION	PASS/COMPLIANCE		NOTES/ACTIONS (If a corrective action is required, provide a description.)
NO.	DATE		YES	NO	
SPECIAL INSTRUCTIONS					
1		In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2		Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1		If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		N/A	
2		Review all zone set points at the server.		N/A	
3		Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4		Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5		Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6		If applicable, replace battery as needed.		N/A	

Note: The technician shall perform emergency maintenance as needed.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

SET WARM

ACTUAL

63

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 -01

MECHANIC

SIGNATURE:

Harry Berthel

DATE:

4/9/19

LOCATION/RM #:

109

WO#

8244

ASSET #

5898

START TIME:

1050

FINISH TIME:

1150

CHECK (INITIALS)	CHECKPOINT DESCRIPTION	PASS/COMPLIANCE		NOTES/ACTIONS (IF NOT COMPLIANT, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		N/A	
2	Review all zone set points at the server.		N/A	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.		N/A	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set 72

Actual 77

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 - C1

MECHANIC

SIGNATURE:

Laurie Bantz

DATE:

4/9/19

LOCATION/RM #:

103

WO#

2244

ASSET #

5899

START TIME:

1100

FINISH TIME:

1110

CHECKS (CONT)		CHECKPOINT DESCRIPTION	DATE COMPLETED		START TIME: 1100	FINISH TIME: 1115
			YES	NO	NOTES/ACTIONS (If not completed, provide explanation)	
SPECIAL INSTRUCTIONS						
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			/		
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			/		
TO BE PERFORMED AT EACH INSPECTION SERVICE						
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.			SL		
2	Review all zone set points at the server.			SL		
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.					
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/				
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/				
6	If applicable, replace battery as needed.	/				
Note: The technician shall perform any repairs identified during this inspection.						

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

Set 70 Actual 62

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050-01

MECHANIC

SIGNATURE:

Gary Butte

DATE:

4/9/19

LOCATION/RM #:

WO#

8244

ASSET #

6229

START TIME:

11:00

FINISH TIME:

11:20

CHECK NO.	CHECKPOINT DESCRIPTION	PASS/COMPLETE		NOTES/ACTIONS (If not completed, provide explanation)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.			
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.			
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.			
2	Review all zone set points at the server.			
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.			
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.			
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.			
6	If applicable, replace battery as needed.			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

2 PC

SET

Sensor

Actual

72

Sensor

79

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST THERMOSTATS

SITE AND BLDG #:

PA 050 -01

MECHANIC

SIGNATURE:

Gary Bertzo

DATE:

4/9/19

LOCATION/RM #:

114

WO# 8244

ASSET #

6205

START TIME:

1120

FINISH TIME:

1120

CHECK POINT	CHECKPOINT DESCRIPTION	TESTS/COMPLETION		NOTES/ACTIONS
		YES	NO	
SPECIAL INSTRUCTIONS				
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered.		/	
2	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		/	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	If EMS (Energy Management System) exists, run the manufacturers diagnostic software for the wireless system. This diagnostic shall produce a report of all functional aspects of the wireless system indicating faults that should be addressed in this maintenance.		N/A	
2	Review all zone set points at the server.		N/A	
3	Inspect thermostat installation; ensure mounting is correct, fastened secure and that the thermostat is not blocked by equipment generating heat or furniture blocking air circulation.	/		
4	Remove thermostat cover and lightly blow away any accumulated dust with canned low pressure air.	/		
5	Check time-of-day schedule to confirm consistency with facility operation. Adjust schedule as needed.	/		
6	If applicable, replace battery as needed.		N/A	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: HVAC Technician

Additional Notes:

2 PC

Set Sensor
Sensor

Actuator 72
70