

Date: 12/27/2023

Region: 4A
FAC ID: NY030

CSS No.: 95961
Maximo WO No.: 14524

Asset #: NA

Priority: Emergency



Original Work Request:

During site visit I discovered that boiler #1 is leaking quite a bit of water.

Description of Repairs Needed:

Labor to a.) to troubleshoot/operations check on two Lochinvar boilers.

Labor:

| | Labor Hrs | Labor Rate | Total |
|-------------|-----------|------------|-------------|
| Technician | 16 | \$ 128.00 | \$ 2,048.00 |
| Trip Charge | 1 | \$ 50.00 | \$ 50.00 |

Material List:

| | Quantity | Cost | Total |
|--|----------|------|-------|
| | | | |
| | | | |
| | | \$ | - |
| | | \$ | - |

Equipment List:

| | Quantity | Cost | Total |
|--|----------|------|-------|
| | | \$ | - |
| | | \$ | - |
| | | \$ | - |

PM WO History:

NA

Estimate Summary:

| Labor | Material | Equipment |
|-------------|----------|-----------|
| \$ 2,098.00 | \$ - | \$ 0.00 |

| Sub Total | G&A 12% | Fee 6% | Total Estimate |
|-------------|-----------|-----------|----------------|
| \$ 2,098.00 | \$ 251.76 | \$ 125.88 | \$ 2,475.64 |



December 22, 2023

US Army Reserve
3126 Upper Lake Road
Horseheads, NY 14845

Attn: Karlee Demain

Re: Boiler troubleshooting

Ms. Demain,

Postler & Jaeckle Service is pleased to quote troubleshooting 2 boilers at your Horseheads location to determine the problems and prepare a repair quote including labor and materials for your approval. One boiler is missing parts that were used on other boilers and the other has a leaking heat exchanger that needs replacement. Your cost for this service will be 16 hours of labor at \$128.00/ hr. and 50 truck charge for a total of \$2,098.00. This proposal is based on work being performed during normal working hours of 8:00am to 4:30pm Monday through Friday. Please contact me with any questions or concerns.

Sincerely,

DAVE HENDEE
Field Sales Support
Postler & Jaeckle Corp.
2000 Lake Rd., Elmira, NY 14903
T 607-739-8303 | C 607-215-6523
E: dhendee@postler.com