



ENERGY MANAGEMENT TECHNOLOGIES, LLC

5 HEMLOCK STREET

LATHAM, NEW YORK 12110

518.783-7810

FAX: 518.783-2079

PROPOSAL

May 28, 2021

CMI Management
Attn: Joe Bayne

Original CSS# 30721
EMTech Initial Field Report# 6490

Subject: No Air Conditioning at Saugerties Location

Scope of Service:

EMTech proposes to supply all labor and material needed to complete the following

- Remove faulty York supply and return water temperature sensors
- Replace both sensors with new
- Check for proper temperature
- Test operation

For the above work, we quote: \$806.00.....Eight Hundred and Six Dollars.

Any and all taxes are not included.

The above is broken down as follows: \$372.00 **Labor**
 \$280.00 **Material**
 \$154.00 **Travel**

Thank you for continuing to include EMTech on your energy team. As always, we look forward to working with you. Please feel free to contact for any questions or concerns you may have on this project.

Sincerely,

Jenna Caligaris
Service Coordinator