

**PROJECT ESTIMATE**

DATE: 04/30/2019

QUOTE ID:	3677	CONTACT:	RON VOGT - CELL
AR CUSTOMER:	CMI MANAGEMENT (#10343)	DATE	Ph:(315) 772-8801
SERVICE LOCATION:	US ARMY RESERVE - PL	SUBMITTED:	Fax:(315) 772-6336
STREET:	5363 PERU STREET, ROUTE 9	PREPARED BY:	steve.miller@cmimgmt.com
CITY:	PLATTSBURGH, NY 12901		

DESCRIPTION: Test Ports

SCOPE OF WORK: We were asked to check your Backflow Preventer (Conbraco Model # UT603, Serial # 40218T2). Our technician noted that the failure found during the inspection was due to leaking ports. He is recommending that the ports be replaced. The backflow preventer is in good shape otherwise and does not appear to have any other issues. The pricing shown below covers labor and materials required to do this work. The diagnostic call is being invoiced separately. Please call me at extension #236 if you have any questions. Thank you.

ITEM	QUANTITY	UNIT PRICE	TOTAL
Labor Regular Time	2	\$110.00	\$220.00
Ports	2	\$26.40	\$52.80
Environmental Fee	1	\$12.00	\$12.00
Total			\$284.80

SIGNATURE

PRINT NAME

DATE



PROJECT ESTIMATE

DATE: 04/30/2019

All material is guaranteed to be as specified. All work to be completed in a workmanlike manner according to standard practices. Any alteration or deviation from the above specifications involving extra costs will be executed only upon written orders, and will become an extra charge over and above the estimate. All agreements contingent upon strikes, accidents or delays beyond our control. Our technicians are covered by New York State Workers Compensation Insurance.

QUOTE VALID FOR THIRTY (30) DAYS

Credit Card Payments over \$5,000.00 will be charged an additional 3% fee