

Hyde-Stone Mechanical

Contractors, Inc. 22962 Murrock Circle
 Watertown, NY 13601
 315-788-1300 Fax 315-788-9646

To: CMI MANAGEMENT
 PM / 99TH - REGION 2
 5285 SHAWNEE ROAD
 ALEXANDRIA VA 22312
Attn: JOE BAYNE - CMI

Work Address: US ARMY RESERVE #NY054
 5363 PERU STREET
 PLATTSBURGH NY
 12901

QUOTATION

Quote #: 0000000624-000
Quote Type: Work Order
Reference: 21-0006142/PAUL
Cross Ref: 12844
Work Order: n/a
Customer: USARMY054
Terr/sale: HSE
Current Date: Apr 21, 2021
Expiry Date: N/A

| Code | Description | Quantity | UOM | Price | Total | | | | | |
|--|-------------------|----------|-------|--------|--------|--|--|--|--|--|
| PO#12844/NTE\$450.00/CSS#30081 | | | | | | | | | | |
| Initial report was to inspect emergency light in supply building due to buzzing sound. | | | | | | | | | | |
| On 4/19/2021 a technician was dispatched and noted the following; | | | | | | | | | | |
| US Army reserve - report of emergency light buzzing, inspected and found transformer to be bad. New emergency light needed. | | | | | | | | | | |
| LITHONIA EMERGENCY SYSTEMS CAT. NO. ELT24 N MT | | | | | | | | | | |
| The pricing shown below covers labor and materials required to replace the emergency light in the supply building, as well as time spent (LABOR - \$110.00, TRIP CHARGE - \$50.00). Due to the projected cost we ask that the NTE be increased from \$450.00 to \$719.28. Please call me at 315-755-1644 if you have any questions. Thank you. | | | | | | | | | | |
| TECH | Service Tech. | 2.00 | Hours | 110.00 | 220.00 | | | | | |
| N/A | EMERGENCY LIGHT | 1.00 | EA | 327.28 | 327.28 | | | | | |
| | ENVIRONMENTAL FEE | 1.00 | | 12.00 | 12.00 | | | | | |
| BELOW IS TIME SPENT - LABOR & TRIP 4/19/21 | | | | | | | | | | |
| TECH | Service Tech. | 1.00 | Hours | 110.00 | 110.00 | | | | | |
| | TRIP CHARGE | 1.00 | Days | 50.00 | 50.00 | | | | | |
| | | | | | | | | | | |
| Sub Total | | | | | | | | | | |
| 719.28 | | | | | | | | | | |
| | | | | | | | | | | |
| Total Quotation | | | | | | | | | | |
| 719.28 | | | | | | | | | | |