



CUSTOMER QUOTATION NO. 260

CMI Management, Inc.
CMI Management, Inc.
Richard Hicks
5285 Shawnee Road Suite #510
Alexandria VA 22312

Quote Name: 12323
Quote No: 260
Site: MD013 Snuffers School Road
Site Contact: Rick Hicks
Salesperson: Lindsay Ruby
Created Date: 05/21/2020
Valid For: 30 Day(s)

WO#: 12323

CSS Ticket Number: 25204

Problem: No hot water in the training building.

Heater #1 had a fault for "no anode voltage" , took the prover switch to fix Heater #2.
 S&S will need to order a new prover switch, install it then troubleshoot the original fault.
 S&S further diagnosed that heater #1 will need two rod replacements.
 S&S will remove and replace the faulty parts and ensure everything is working properly.

Service

Item	Quantity	Unit Price	Total
Blwr Prover Switch / S100111056	1.00	\$90.24	\$90.24
Tax	1.00	\$4.51	\$4.51
48 Pwr Rod Kit	1	\$470.44	\$470.44
13.78 Pwr and Rod Kit	1	\$183.54	\$183.54
Tax	1	\$32.70	\$32.70
Shipping	1	\$100.00	\$100.00
Diagnosis Fee	1	\$300.00	\$300.00
Plumbing Labor Rate	12	\$100.00	\$1,200.00
Sub-Total ex Tax		\$2,381.43	
Tax		\$0.00	
Total inc Tax		\$2,381.43	

Labor	\$1,500.00
Materials	\$881.43
Sub-Total ex Tax	\$2,381.43
Tax	\$0.00
Total inc Tax	\$2,381.43