



CUSTOMER QUOTATION NO. 285

Tidewater, Inc.
Tidewater, Inc
6625 Selnick Dr.
Suite A
Elkridge MD 21075

Quote Name: 11974
Quote No: 285
Site: DE007 Olgetown Road
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 06/22/2020
Valid For: 30 Day(s)

WO#: 11974

CSS Ticket Number: 2452

Problem: BF failed testing.

S&S was onsite and diagnosed the 2" backflow serial # RPZE has two damaged and corroded test port.

S&S was onsite and diagnosed the 1" backflow serial # G7985 needed to be replaced.

S&S will do a full replacement on both backflows.

S&S will then perform a test on the device to ensure it is working properly.

S&S also found a third backflow that needs replacement but all parts are obsolete and we will need to check the dimensions to find parts that are compatible. S&S will do this while onsite performing the above work.

Service

Item	Quantity	Unit Price	Total
Diagnostic Total	1.00	\$550.00	\$550.00
Testing	1.00	\$150.00	\$150.00
LF 1 BRZ IPS	1.00	\$348.50	\$348.50
LF 3/8 BRS 600#	2.00	\$12.77	\$25.54
LF 3/8 x 1-1/2 BRS NIP GBL	2.00	\$5.03	\$10.06
1 x 10 L Hard Cop Tube	1.00	\$39.37	\$39.37
LF 1 PXP Coup W St	1.00	\$7.86	\$7.86
LF 1 PXP Coup L St	2.00	\$10.70	\$21.40
Tax	1.00	\$22.39	\$22.39
Shipping	1.00	\$100.00	\$100.00
Plumbing Labor Rate	14	\$100.00	\$1,400.00
		Sub-Total ex Tax	\$2,675.12
		Tax	\$0.00
		Total inc Tax	\$2,675.12

Labor	\$1,400.00
Materials	\$1,275.12
Sub-Total ex Tax	\$2,675.12
Tax	\$0.00
Total inc Tax	\$2,675.12