



CUSTOMER QUOTATION NO. 300

Tidewater, Inc.
Tidewater, Inc
6625 Selnick Dr.
Suite A
Elkridge MD 21075

Quote Name: 11765
Quote No: 300
Site: MD002 Ordnance Road
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 07/06/2020
Valid For: 30 Day(s)

WO#: 11765

CSS Ticket Number: 20482

Problem: Units still not cooling since repair 10/28/19 WO 10592.

S&S was onsite and found that the blower motor was in operation but was constantly running.
 S&S proposes to remove and replace the control head and relay hybrid.
 S&S will then complete a system check to ensure everything is running properly.

Service

Item	Quantity	Unit Price	Total
Diagnostic Total	1.00	\$350.00	\$350.00
Relay Hybrid/ 192226	1.00	\$105.94	\$105.94
Control Head/ 235741	1.00	\$649.88	\$649.88
Shipping	1.00	\$100.00	\$100.00
Refrigeration Labor Rate	10	\$100.00	\$1,000.00
		Sub-Total ex Tax	\$2,205.82
		Tax	\$0.00
		Total inc Tax	\$2,205.82
		Labor	\$1,000.00
		Materials	\$1,205.82
		Sub-Total ex Tax	\$2,205.82
		Tax	\$0.00
		Total inc Tax	\$2,205.82