



## CUSTOMER QUOTATION NO. 333

CMI Management, Inc.  
CMI Management, Inc.  
Richard Hicks  
5285 Shawnee Road Suite #510  
Alexandria VA 22312

**Quote Name:** 12459  
**Quote No:** 333  
**Site:** VA002 Telegraph Road  
**Site Contact:** Rick Hicks  
**Salesperson:** Lindsay Ruby  
**Created Date:** 07/30/2020  
**Valid For:** 30 Day(s)

**WO#:** 12459

**CSS Ticket Number:** 25711

**Problem:** Both chilled water pumps were overloaded and off line from an electric pole issue in front the property previously this week. Reset both pumps and manually started water flow. The system will not control the pumps as intended. Pump 1 is in manual override, and chiller will disable upon set point.

S&S proposes to install new fan motors in rooms 117 & 119.

S&S will remove and replace faulty actuators in rooms 113, 119, 123, 125, 201, 202, 207, 209 & 213.

S&S will replace the transformers in room 113 FCU 19, 20 & 23.

S&S will then complete a system check to ensure everything is working properly.

### Service

Item	Quantity	Unit Price	Total
Motor / 152182	2.00	\$326.34	\$652.68
Actuator / 226970	9.00	\$94.90	\$854.10
Transformer / 88636	1.00	\$15.96	\$15.96
Shipping	1.00	\$100.00	\$100.00
Diagnosis Fee	1	\$300.00	\$300.00
HVAC Labor Rate	20	\$100.00	\$2,000.00
<b>Sub-Total ex Tax</b>		\$3,922.74	
<b>Tax</b>		\$0.00	
<b>Total inc Tax</b>		\$3,922.74	

<b>Labor</b>	\$2,300.00
<b>Materials</b>	\$1,622.74
<b>Sub-Total ex Tax</b>	\$3,922.74
<b>Tax</b>	\$0.00
<b>Total inc Tax</b>	\$3,922.74