



S&S MECHANICAL

S&S Mechanical
4845 South Crain Highway
Upper Marlboro, MD 20772

Tel. 1 - (301) 574-1555
Fax. 1 - (301) 574-1558
www.sandsmidatlantic.com

CUSTOMER QUOTATION NO. 421

CMI Management, Inc.
CMI Management, Inc.
Richard Hicks
5285 Shawnee Road Suite #510
Alexandria VA 22312

Quote Name: 13135
Quote No: 421
Site: MD013 Snouffers School Road
Site Contact: Rick Hicks
Salesperson: Lindsay Ruby
Created Date: 10/30/2020
Valid For: 30 Day(s)

WO#: 13135

CSS Ticket Number: 27421

Problem: NO HOT WATER IN TRAINING BUILDING, This is an ongoing issue with this water heater, please make repairs to correct this issue.

S&S was onsite and found the building had no hot water because heater #1 was not able to be controlled due to the screen and control buttons being locked up. Changed the heater over since heater #2 is not being used allowing hot water to building. S&S proposes to replace the display overlay in heater # 2 and check the operation to ensure everything is working properly. S&S was onsite replacing the overlay and found the display module will also need to be replaced.

*Module lead time is 5 days.

Service

Item	Quantity	Unit Price	Total
CVR KIT SUF DISPLAY OVERLAY	1.00	\$186.37	\$186.37
Module/ S10011017	1.00	\$195.70	\$195.70
Shipping	1.00	\$50.00	\$50.00
Diagnosis Fee	1	\$400.00	\$400.00
Plumbing Labor Rate	12	\$100.00	\$1,200.00
Sub-Total ex Tax			\$2,032.07
Tax			\$0.00
Total inc Tax			\$2,032.07

Labor	\$1,600.00
Materials	\$432.07
Sub-Total ex Tax	\$2,032.07
Tax	\$0.00
Total inc Tax	\$2,032.07