



CUSTOMER QUOTATION NO. 597

CMI Management, Inc.
5285 Shawnee Road Suite #510
Alexandria VA 22312

Quote Name: 13859
Quote No: 597
Site: MD066 Fox Tail Avenue
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 05/06/2021
Valid For: 30 Day(s)

WO#: 13859

CSS Ticket Number: 29391

Problem: Location is in the storage/cage area of bldg.1. Back near the offices. Unit is running but louvers are not open. BLDG EMS has fan in alarm.

S&S was onsite and found that the fan was shoved through the entire wall and not mounted on the back of the wall. S&S proposes to return and install a Honeywell damper actuator. S&S will then complete a system check to ensure the system is running correctly.

Service

Item	Quantity	Unit Price	Total
Scaffolding	1.00	\$250.00	\$250.00
Actuator Damper	1.00	\$426.17	\$426.17
Diagnosis Fee	1	\$1,000.00	\$1,000.00
HVAC Labor Rate	20	\$100.00	\$2,000.00
		Sub-Total ex Tax	\$3,676.17
		Tax	\$0.00
		Total inc Tax	\$3,676.17
		Labor	\$3,000.00
		Materials	\$676.17
		Sub-Total ex Tax	\$3,676.17
		Tax	\$0.00
		Total inc Tax	\$3,676.17