



CUSTOMER QUOTATION NO. 675

CMI Management, Inc.
5285 Shawnee Road Suite #510
Alexandria VA 22312

Quote Name: 14555
Quote No: 675
Site: MD066 Fox Tail Avenue
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 08/02/2021
Valid For: 30 Day(s)

WO#: 14555

CSS Ticket Number: 31623

Problem: Circuit 1 Compressor in Alarm, High Head pressure.

S&S proposes to remove and replace the Scroll Copeland compressor on Circuit 1.
S&S will then complete a system check to ensure the system is working properly.

Service

Item	Quantity	Unit Price	Total
COMPRESSOR SCRL 13HP 155BTU 460/60/3	1.00	\$2,455.42	\$2,455.42
R410a Refrigerant	1.00	\$359.99	\$359.99
R56-199 95150 SIL-FOS ALLOY 15%	1.00	\$158.40	\$158.40
CD30 CLEAN TANK ONLY 50	1	\$158.40	\$158.40
Shipping	1.00	\$350.00	\$350.00
Diagnosis Fee	1	\$250.00	\$250.00
HVAC Labor Rate	20	\$100.00	\$2,000.00
Sub-Total ex Tax			\$5,732.21
Tax			\$0.00
Total inc Tax			\$5,732.21

Labor	\$2,250.00
Materials	\$3,482.21
Sub-Total ex Tax	\$5,732.21
Tax	\$0.00
Total inc Tax	\$5,732.21