



CUSTOMER QUOTATION NO. 945

CMI Management, Inc.
5285 Shawnee Road Suite #510
Alexandria VA 22312

Quote Name: 16792
Quote No: 945
Site: MD066 Fox Tail Avenue
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 03/14/2022
Valid For: 30 Day(s)

WO#: 16792

CSS Ticket Number: 34928

Problem: HVAC TECH Callers' description of the problem or requirement:
Repair Heat PumpsPOC is Michael Cloaninger@ 910-598-8408

HP-1-26 corridor c-103/ no communication with bldg. Mgmt
 HP-2-05 rm.222/ had a electrical/smoke smell at one point. Unit is off as of now.
 HP-2-12 rm.204/ Temp sensor fail
 HP-2-17 rm.209/208/suction Temp sensor fail
 HP-2-20 rm. 228/ comp. Low pressure
 HP-2-26 rm. 243/ comp. Low suction

S&S proposes to replace (5) control board modules & (5) control board MT111 in WSHP on the DOAS. S&S will then complete a system check to ensure everything is running properly.

Service

Item	Quantity	Unit Price	Total
CONTROL BOARD COMM MODULE LON	5.00	\$475.52	\$2,377.60
CONTROL BOARD MTIII	5.00	\$153.04	\$765.20
Shipping	1	\$100.00	\$100.00
Diagnosis Fee	1	\$400.00	\$400.00
HVAC Labor Rate	20	\$100.00	\$2,000.00
Sub-Total ex Tax		\$5,642.80	
Tax		\$0.00	
Total inc Tax		\$5,642.80	

Labor	\$2,400.00
Materials	\$3,242.80
Sub-Total ex Tax	\$5,642.80
Tax	\$0.00
Total inc Tax	\$5,642.80