



CUSTOMER QUOTATION NO. 963

CMI Management, Inc.
CMI Management, Inc.
Richard Hicks
5285 Shawnee Road Suite #510
Alexandria VA 22312

Quote Name: 16911
Quote No: 963
Site: VA002 Telegraph Road
Site Contact: Rick Hicks
Salesperson: Lindsay Ruby
Created Date: 03/25/2022
Valid For: 30 Day(s)

WO#: 16911

CSS Ticket Number: 35208

Problem: The hot water booster pump at VA002. Turning on and off about every 3 minutes, very hot, and rattling noise.

Asset # 2226HWTP#01

POC Evan Usner 318-787-1920

Troubleshoot B&G hot water booster pump. Tried greasing, cleaning and repositioning internal parts with no success. The pump appears to be stalling out immediately after activation. S&S will remove and replace the booster pump and then complete a system check to ensure everything is working properly.

**Pump is in stock*

Service

Item	Quantity	Unit Price	Total
LF 1/12HP 100BNFI CIRC PUMP 115V	1.00	\$1,200.86	\$1,200.86
Shipping	1.00	\$100.00	\$100.00
Diagnosis Fee	1	\$450.00	\$450.00
Plumbing Labor Rate	8	\$100.00	\$800.00
Electrical Labor Rate	8	\$100.00	\$800.00

Sub-Total ex Tax	\$3,350.86
Tax	\$0.00
Total inc Tax	\$3,350.86

Labor	\$2,050.00
Materials	\$1,300.86
Sub-Total ex Tax	\$3,350.86
Tax	\$0.00
Total inc Tax	\$3,350.86