



## OneCIS Insurance Company

95 Oakwood Rd  
Lake Zurich, IL 60047  
(855) 593-5115  
[www.us.bureauveritas.com](http://www.us.bureauveritas.com)

May 20, 2019

44110-007209.00

USARC BG J Sumner Jones  
11 Veteran Blvd  
Romney, WV 26757  
[bernie.koblinsky@cmimgmt.com](mailto:bernie.koblinsky@cmimgmt.com)

**RE: Jurisdictional Inspection:**  
USARC BG J Sumner Jones  
11 Veteran Blvd  
Romney, WV 26757

Thank you for the consideration I received during my visit on May 2, 2019 at your facility listed above. The purpose of the visit was to perform the non-jurisdictional inspections of the objects listed below to determine compliance with jurisdictional laws and regulations. I was accompanied by SFC Michael Moore during my visit.

The inspections were performed on behalf of CMI Management, Inc (US Army Reserve Offices).

The following objects were inspected at the time of the visit:

| Year Built | Type of object | Jurisdictional Number | NB Number | Recommendation(s) |
|------------|----------------|-----------------------|-----------|-------------------|
| 2000       | Cast Iron      | WV038-01              | CI        | See Below         |
| 2000       | Cast Iron      | WV038-02              | CI        | See Below         |
| 2000       | Cast Iron      | WV038-03              | CI        | None              |

The following observations were noted during the inspection of this equipment:

- ***Fittings, attachments, and accessible parts were closely examined and found in satisfactory condition. No adverse conditions were noted with respect to controls and safety valves.***

As a result of this inspection, there were 2 recommendations suggested.

In order for the certificate(s) of operation to be renewed, all code violations must be cleared.

The recommendation(s) made to correct the deficiency(s) are listed below. Please indicate any action(s) taken on these recommendation(s), by calling me at the number listed below.

The next inspection is tentatively scheduled to be completed by 08/02/2019.

## **Recommendations**

The following recommendation(s) must be completed before an operating permit can be issued.

No. **2019-05-1** - Complete within 90 days  
WMSD-WV038-01 located in Boiler Room

**Condition:** The ASME code stamping plate is missing or indistinct

**Requirement:** Contact the manufacturer to have a replacement ASME code stamping decal applied.

No. **2019-05-2** - Complete within 90 days  
WMSD-WV038-02 located in Boiler Room

**Condition:** The ASME code stamping plate is missing or indistinct.

**Requirement:** Contact the manufacturer to have a replacement ASME code stamping decal applied.

Please contact me by phone at 571-373-0998 or by e-mail at [william.johnson@onecis.com](mailto:william.johnson@onecis.com) if there are any questions and to clear any recommendations.

Sincerely,

*William Garth Johnson*

William Garth Johnson  
B&M Jurisdictional Specialist

## DISTRIBUTION

Cc:

Thomas Kovach, OneCIS Insurance  
[Thomas.kkovach@onecis.com](mailto:Thomas.kkovach@onecis.com)

## FILE

This document is advisory in nature. Reports or certificates provided in connection with any state-required boiler or pressure vessel inspection do not mean that all hazards or conditions were controlled at the time of the inspection. No liability is assumed by the information contained in this document.

# Location Detail

Search Criteria: Country: USA; NOB/SIC: ;Address 1: ;City: ;Zip: ;County: ;FIPS Code: ;Status: Active; Order Results by: Location Name; Then Order by: Address

Policy Name: CMI Management, Inc (US Army Reserve Offices) Policy Number: 44110-007209.00  
Location: USARC BG J Sumner Jones Location ID: 3933729  
Address: 11 Veteran Blvd - Romney, WV 26757 Phone:  
County: Hampshire FIPS: 54027 NOB/SIC:  
Primary Contact: Bernie Koblinsky - Phone: 703-738-5303 - Email: bernie.koblinsky@cmimgmt.com  
Billing Contact: Bernie Koblinsky - 5285 Shawnee Rd Ste 510 Alexandria, VA 22312-2334 - Phone: 703-738-5303 - Email: bernie.koblinsky@cmimgmt.com  
Registered Owner's Email (NYC Locations Only):

| Juris #  | Alt Juris # | Type      | Use              | NB | Serial      | Manufacturer | Year Built | Due Date   | Inspect Type   | Status | Location    |
|----------|-------------|-----------|------------------|----|-------------|--------------|------------|------------|----------------|--------|-------------|
| WV038-01 |             | Cast Iron | Hot Water Supply | CI |             | WMSD         | 2000       | 05/02/2020 | Recurring Cert | Active | Boiler Room |
| WV038-02 |             | Cast Iron | Hot Water Supply | CI |             | WMSD         | 2000       | 05/02/2020 | Recurring Cert | Active | Boiler Room |
| WV038-03 |             | Cast Iron | Hot Water Supply | CI | S?N64252253 | Burnham      | 2000       | 05/02/2020 | Recurring Cert | Active | Boiler Room |

Total Objects at this Location: 3

Total Objects 3  
Total Locations 1  
Total Active Objects 3