

Date: 6/2/2025

Region: 4C

FEMS No.: 3031136

FAC ID: WV029

Maximo WO No.: 18449

Asset #: NA

Priority: Urgent



Original Work Request:

Repair gate and cameras. We cannot get anything to come back online. Gate can be manually opened and closed at this time.

Description of Repairs Needed:

Labor and material to diagnose and repair if possible the issues being experienced with the CCTV and Access Control including the replacement of the 16 Port PoE Switch and 24V Power Supply per above description. Found 5/30/2025 when on site to replace, found loop wire cut to Gate operator, pulled new wire, now normal. Found entire rack dead due to bad UPS need replacement. Found basement monitor dead. Need new monitor. Will provide separate quote.

Labor:

	Labor Hrs	Labor Rate	Total
Technicians (2 Tech x 16 hrs)	32	\$ 95.00	\$ 3,040.00
Administration	1	\$ 100.00	\$ 100.00

Material List:

	Quantity	Cost	Total
		\$	-
		\$	-
		\$	-
		\$	-
		\$	-
		\$	-
		\$	-

Equipment List:

	Quantity	Cost	Total
		\$	-
		\$	-
		\$	-

PM WO History:

NA

Estimate Summary:

Labor	Material	Equipment
\$ 3,140.00	\$ -	\$ 0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$ 3,140.00	\$ 376.80	\$ 188.40	\$ 3,705.20

LoCurrent Systems, LLC

3522 County Highway 11
Cooperstown, NY 13326
(607)293-7300
locurrent@gmail.com



INVOICE

BILL TO

Tidewater Inc.
6625- A Selnick Drive
Elkridge, MD 21075

INVOICE # 2887**DATE** 05/30/2025**DUE DATE** 06/29/2025**TERMS** Net 30**P.O. NUMBER**

Morgantown, WV CAC & CCTV Serv.

ACTIVITY	QTY	RATE	AMOUNT
Services			
As per Estimate #2637	1	3,140.00	3,140.00
Morgantown, WV USARC			
Diag. & Repair Access Control/CCTV			
(FEMS# 301136)			

Dear Ms. Pape,

As per your request, LoCurrent Systems is pleased to provide a quotation to diagnose and repair if possible the issues being experienced with the CCTV and Access Control. Upon our Service Technician's diagnosis, a follow up quotation was provided, Estimate #2703.

Cost Breakdown:

(2) men 16 hrs @ \$95.....\$3,040.00

Administration.....\$100.00

Grand Total.....\$3,140.00

The cost for the above mentioned work is \$3,140.00.

If acceptable, please do not hesitate so that we may schedule for service to be completed.

Thank you for thinking of LoCurrent Systems.

Sincerely,

Antonietta LoRusso

If you have any questions regarding this invoice, please contact Antonietta LoRusso at (607)293-7300.

BALANCE DUE

\$3,140.00