



## CUSTOMER QUOTATION NO. 913

CMI Management, Inc.  
CMI Management, Inc.  
Richard Hicks  
5285 Shawnee Road Suite #510  
Alexandria VA 22312

**Quote Name:** 16760  
**Quote No:** 913  
**Site:** MD021 Baltimore Road  
**Site Contact:** Rick Hicks  
**Salesperson:** Lindsay Ruby  
**Created Date:** 02/22/2022  
**Valid For:** 30 Day(s)

**WO# 16760**

**CSS Ticket Number: 34684**

**Problem:** BAC is not working, all AHU are off line.

POC Thaddeus 843-217-3346

S&S found BAS is not reading temp correctly, S&S proposes to remove and replace the Trane return water temperature sensor. S&S will then complete a system check to ensure everything is working properly.  
S&S further found the Netgear ethernet switch not operating and recommend replacement

**Take pictures and fill out a COW ticket.**

### Service

Item	Quantity	Unit Price	Total
Trane Temp Sensor	1.00	\$34.04	\$34.04
Shipping	1.00	\$25.00	\$25.00
Netgear Ethernet Switch	1	\$45.59	\$45.59
Diagnosis Fee	1	\$1,100.00	\$1,100.00
HVAC Labor Rate	6	\$100.00	\$600.00
<b>Sub-Total ex Tax</b>		\$1,804.63	
<b>Tax</b>		\$0.00	
<b>Total inc Tax</b>		\$1,804.63	

<b>Labor</b>	\$1,700.00
<b>Materials</b>	\$104.63
<b>Sub-Total ex Tax</b>	\$1,804.63
<b>Tax</b>	\$0.00
<b>Total inc Tax</b>	\$1,804.63