



Date: 4/12/2023

Region: 4A
FAC ID: NY070

CSS No.: 91593
Maximo Work Order No.: 12030

Asset #: NA

Original Work Request:

Replace 4 safety edge strips on the overhead bay doors in shop.

Description of Repairs Needed:

Labor and material to a.) replace electric safety edge with retainer and take up reel on 4 doors, (Miller ME-123 edge, Miller ME123-C3 retainer, Miller ME-182 take up reel)

Material List:

- (4) Miller ME-123 edge
- (4) Miller ME123-C3 retainer
- (4) Miller ME-182 take up reel

Equipment List:

NA

PM WO History:

NA

Estimate Summary:

Labor Hours	Labor	Material/Equipment	Total Repair
10	\$1,393.80	\$3,252.20	\$4,646.80