



Date: 3/15/2023

Region: 4C
FAC ID: WV009

CSS No.: 91850
Maximo Work Order No.: 12055

Asset #: NA

Original Work Request:

Rebuild and retest failed backflow

Description of Repairs Needed:

Labor and material to a.) rebuild and retest the failed backflow.

Material List:

(1) 794070 WATTS 1 1/4-2" LFRK 909M1 RT - AMERICAN
BAC
(1) 794071 WATTS 1 1/4-2" LFRK 909M1 T - AMERICAN
BACK

Equipment List:

NA

PM WO History:

NA

Estimate Summary:

Labor Hours	Labor	Material/Equipment	Total Repair
11	\$1,590.45	\$1,486.98	\$3,077.43