

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
REACH-IN REFRIGERATORS/ FREEZERS

SITE AND BLDG #: VA001

MECHANIC
SIGNATURE: 

DATE: 8/2/23

LOCATION/RM #: WO# 13560 ASSET # 6788

START TIME: 10AM

FINISH TIME: 11AM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	De-energize, lock out, and tag electrical circuits.		●	
2	If appliance is disposed, follow regulations concerning removal of refrigerants and disposal of the appliance.		●	
TO BE PERFORMED AT EACH INSPECTION				
1	Check with operating or area personnel for any deficiencies; verify cleaning program.		●	
2	Verify indicator light on; check compartment temperature.		●	
3	Examine evaporator for proper clearances/slope and air flow.		●	
4	Examine handles, hinges and tightness of door closure.		●	
5	Examine safety door release and fan shut down safety switch.		●	
6	Inspect lighting for burnt out lamps. Replace if required.		●	
7	Clean evaporator coil, evaporator drain pan, blowers, fans, motors, and drain piping as required; lubricate motor(s).		●	
8	Clean condenser coil and condensing unit section.		●	
9	Clean and inspect defrost evaporation trays/pans.		●	
10	Check operation of thermostats; calibrated as required.		●	
11	Check coil superheat and adjust to manufacturers recommendations.		●	
12	Inspect and service all electric motors.		●	
13	Check box floor for water or ice accumulation.		●	
14	Clean up area and note any deficiencies.		●	



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

This Freezer does not work wand will need replaced
-AS

