

**CERTIFICATION OF WORK**  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV046

Date of Visit: 6/6/2024

Contractor Personnel on Site:

1. Kyle Dean

2. \_\_\_\_\_

**Work Performed:**

**Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)**

1. WO# 206546

**Service Calls – Service Call Number and Description**

1. CSS# 93826 WO15403
2. CSS# \_\_\_\_\_
3. CSS# \_\_\_\_\_

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Jesse Biddle Date: 6/6/2024

Signed: 

To be signed by Facility Manager:

I certify that the above named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed:

Print Name/Rank: Kyle Dean Date: 6/6/2024

Signed: 

E-Mail: kyle.d.dean3.mil@army.mil

CASTO TECHNICAL SERVICES, INC.

## SERVICE REPORT

DATE 2024/06/06 ARRIVAL TIME 9:00am

DEPARTURE TIME 3:30pm

JOB/TICK NO 206546

CUSTOMER PO. NO. **CSS#93826**

**JOB NAME/LOCATION** USARC - Parkersburg WV046

**SERVICE REQUESTED** (10) Investment is to Rewire, Repipe, install a new Pressure Switch, and add Glycol to both Glycol Feeders to

Manufacture: _____
Model#: _____
Serial#: _____
Refrigerant Added:      Qty      lb      oz      TYPE
Refrigerant Removed:      Qty      lb      oz      TYPE

- Leak Tested**
- Leak Found**
- Leak Repaired**

**Method:** \_\_\_\_\_

**Total Charge:** \_\_\_\_\_

**WORK PERFORMED/UNIT INFO**

I arrived onsite and checked in. I found the glycol feeder had gotten wired back up at the training building and was working properly. I repiped in the glycol feeder at the OMS building and found the taco pump was leaking. I went through the building looking for other leaks that need fixed before I put in the glycol. I talked to Tom and he said we wasn't supposed to be working on the glycol feeders and that the pott feeder description was correct even though we checked with Jennifer before quoting to get the glycol feeders back up and running. We will wait to see what needs to happen going forward.

**NATURE OF WORK**

Regular Service \_\_\_\_\_

Quoted Service  \_\_\_\_\_

Start-up/Warranty \_\_\_\_\_

SPD \_\_\_\_\_

Contract Service \_\_\_\_\_

Energy Management \_\_\_\_\_

**PARTS, MATERIALS AND SUBCONTRACTED SERVICES**

## **SUMMARY OF TIME**

**JOB COMPLETE**

YES \_\_\_\_\_ NO \_\_\_\_\_ EXPLAIN \_\_\_\_\_

**SIGNATURE** \_\_\_\_\_

### **Customer Representative**