

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY030 Date of Visit: 12/11/23

Contractor Personnel on Site:

1. <u>Postler and Jaeckle</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 95150 WO# 14074

Description of Repairs

Found no power to indoor wall mounted thermostat, removed all paneling to indoor heater unit to access control board. Found that the board has overheated and shows indication on plastic cover. Fuse F1 for power supply to indoor board which is located on the outdoor board has blown. Both a new fuse with a spare and indoor control board are required to continue pursuing with system

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Karlee Demain Date: 12/20/23

Signed: _____

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: John F. Granata Date: 21 Dec 2023

Signed: John F. Granata

E-Mail: john.f.granata.ctr@army.mil